

STATIC WIDE FRAME CURTAIN FIRE DAMPER 3 HR. LABEL • VERTICAL MOUNT FOR USE IN STATIC SYSTEMS MODELS: 0540V (TYPE A)

QUALIFICATIONS:

- UL 555 & CAN/ULC-S112 CLASSIFIED FIRE DAMPER. 3 hr. label (File # R9492).
- Meets all the requirements of UL and NFPA 80, 90A and 101 for fire dampers in static HVAC systems, as well as IBC and NBC (Canada) Building Code requirements.
- City of New York Board of Standards and Appeals. Cal. No. 460-88-SA.
- California State Fire Marshal: Fire Damper Listing No. 3225-0935:0100.

Model 0540 curtain fire damper is UL approved for use where local building codes require the protection of HVAC ductwork penetrations in walls or partitions that have a fire resistance rating of up to 4 hours. The 0540 is classified for use only in static "fans off" systems where the HVAC system is automatically shut down in the event of a fire alarm. The wide frame design reduces the number of blades required in the curtain stack, which increases the free area and therefore reduces the pressure drop across the damper when compared to standard Type A curtain fire damper designs.

STANDARD CONSTRUCTION:

Frame:	6" (152) wide, 22 ga. (0.85) roll-formed G60 galvanized steel.
Blades:	Curtain type interlocking blades, 22 ga. (0.85)
Fusible Link:	roll-formed G60 galvanized steel. 165°F (74°C) standard. UL Listed.
	212°F (100°C) available.
Blade Closure:	Vertical mount model; gravity.

Sizes (W x H):

Minimum	Maximum		
Single Section	Single Section		
Vertical	Vertical		
4" x 4" (102 x 102)	60" x 48" or 24" x 60" (1524 x 1219 or 610 x 1524)		


Note: For horizontal mount applications, contact factory.

OPTIONS:

- □ Non-standard temperature fusible link. Specify
- □ Factory Sleeve. Available in 10 (3.5) through 22 ga. (0.85) galvanized steel and in lengths required for application. Specify: _____ length. ____ ga.

NOTES:

1. See sizing chart for relationship of duct size and damper size. Refer to drawings SC5 and SC6.



	For installation instructions, see IOM-FDINST.			
SCHEDULE TYPE:	Dimensions are in inches (mm).			
PROJECT:				
ENGINEER:	DATE	B SERIES	SUPERSEDES	DRAWING NO.
CONTRACTOR:	4 - 28 - 14	FD	2 - 18 - 05	0540

Nailor Industries Inc. reserves the right to change any information concerning product or pricing without notice.