




LOW PROFILE FAN POWERED TERMINAL UNIT WITH PSC MOTOR

PARALLEL FLOW • VARIABLE VOLUME

MODELS: 37N, 37NW AND 37NE • UNIT SIZES 2, 3 & 4









Dimensional Data

Unit Size	_	w	L	н	A	Induced Air Inlet IWx IH	Outlet Discharge DW x DH	В	J	Filter (Optional) Size
2	6 (152), 8 (203)	32	36	11	7 7/8 (200)	12 x 10	10 x 8	1 1/2	1 1/2	14 x 11
	10 (254)	(813)	(914)	(279)	6 1/2 (165)	(305 x 254)	(254 x 203)	(38)	(38)	(356 x 279)
3	8 (203), 10 (254)	38	36	11	12 (305)	16 x 10	16 x 8	1 1/2	1 1/2	18 x 11
	14 x 8 (356 x 203)	(965)	(914)	(279)	8 1/8 (206)	(406 x 254)	(406 x 203)	(38)	(38)	(457 x 279)
4	14 x 8 (356 x 203)	43	36	12 1/2	13	19 x 10	19 x 11	1	3/4	21 x 11
	14 x 10 (356 x 254)	(1092)	(914)	(318)	(330)	(483 x 254)	(483 x 279)	(25)	(19)	(533 x 279)



DESCRIPTION:

- Only 11" (279) to 12 1/2" (318) high.
- 20 ga. (1.0) galvanized steel construction.
- 2 x 20 ga. (1.0) round or rectangular damper with a polyurethane peripheral gasket. 90° rotation, CW to close. Tight shut-off. Damper leakage is less than 2% of the terminal rated airflow at 3" w.g. (750 pa.) as tested in accordance with ANSI / ASHRAE Standard 130.
- Multi-point averaging Diamond Flow sensor.
- · Access panels top and bottom.
- Energy efficient PSC fan motor with overload protection.
- 1/2" (13) dual density insulation, exposed edges coated to prevent air erosion. Meets requirements of NFPA 90A and UL 181.

SCHEDULE TYPE:

- Single point electrical and/or pneumatic main air connection.
- Discharge opening for flanged duct connection.
- Gasketed backdraft damper mounted on fan discharge.
- Full primary air valve low voltage NEMA 1 type enclosure for factory mounted DDC and analog electronic controls
- Controls mounted as standard on RH side as shown (Right Hand unit).
 Terminals ordered with LH controls (optional) are built as mirror image (Left Hand unit). Inlets and discharge are opposite of drawing.

Options:

- ☐ Filter frame and 1" (25) disposable filter.
- ☐ Induced air attenuator.

Electrical Data

Unit	Motor	PSC MOTOR FLA						
Size	H.P.	120V	208V	240V	277V			
2	1/6	4.6	1.8	1.8	1.3			
3	1/4	5.4	2.2	2.2	1.7			
4	1/2	7.5	3.5	3.5	2.6			

FLA = Full load amperage

- ☐ Toggle disconnect switch.
- ☐ Steri-liner.
- ☐ Fiber-free liner.
- ☐ Solid metal liner.
- ☐ Perforated metal liner.
- ☐ Fan unit fusing.
- ☐ Hanger brackets.
- ☐ Left-hand controls location.
- ☐ Dust tight enclosure seal.
- ☐ Special features

Page 1 of 2.

For heat options; see page 2. Dimensions are in inches (mm).

 PROJECT:
 Dimensions are in inches (mm).

 ENGINEER:
 DATE
 B SERIES
 SUPERSEDES
 DRAWING NO.

 CONTRACTOR:
 6 - 7 - 22
 3700
 3 - 24 - 17
 37N-1



LOW PROFILE FAN POWERED TERMINAL UNIT WITH PSC MOTOR

PARALLEL FLOW • VARIABLE VOLUME

MODELS: 37N, 37NW AND 37NE • UNIT SIZES 2, 3 & 4

☐ Hot Water Coil Section Model 37NW

Standard Features:

- 1/2" (13) copper tubes.
- · Aluminum ripple fins.
- · Sweat connections: 1/2" (13) O. D. male solder. Two row 7/8" (22) O.D. male solder.

Coil Rows:

☐ 1-Row ☐ 2-Row

Coil Hand Connections:

(Looking in direction of airflow).

☐ Left hand (illustrated). Standard.

☐ Right hand (terminals are inverted. Built as mirror image) Optional.

Connections must be selected opposite hand to controls enclosure location.

e r.	C	WATER COIL INDUCED E AIR OPTIONAL INDUCED AIR INDUCED AIR INLET FILTER PRIMARY AIR A A A A A A A A A A A A A A A A A A	BACKDRAFT DAMPER DAMPER	W	DH — DH — I	DW
lt	POINT FLOW	(152)	II DRIVESHAFT	<u> </u>		<u></u>
е	SENSOR	5 1/2" (140)			ü	∱ B
		A	10" (254) - 14" (356) -			

Unit Size	W	L	Н	В	C x D	E	F	G	DW x DH
2	32 (813)	36 (914)	11 (279)	1 1/2 (38)	12 x 10 (305 x 254)	13 (330)	5 (127)	11 (279)	10 x 8 (254 x 203)
3	38 (965)	36 (914)	11 (279)	1 1/2 (38)	16 x 10 (406 x 254)	17 (432)	5 (127)	11 (279)	16 x 8 (406 x 203)
4	43 (1092)	36 (914)	12 1/2 (318)	1 (25)	21 x 10 (533 x 254)	22 (559)	5 (127)	11 (279)	19 x 11 (483 x 279)

OPTIONAL

INDUCED AIR

INLET FILTER

☐ Electric Coil Section Model 37NE

Standard Features:

- Unique hinged heater design permits easy access, removal and replacement of heater element without disturbing ductwork.

- per element).

INDUCED İW Coil installed on unit discharge. FAN AIR Insulated coil element wrapper. Automatic reset high limit cut-outs (one (305) Single point electrical connection (except DIA. = PRIMARY BACKDRAFT 600V) NOM. BUTTERFLY AIR DAMPER -1/8" (3) · Positive pressure airflow switch. DAMPER III HEATER Class A 80/20 Ni/Cr wire. DAMPER MULTI-Magnetic contactors per stage. DRIVESHAFT POINT Flanged outlet duct connection. FAN / HEATER FI OW 5 1/2" (140) PRIMARY Terminal unit with coil is ETL Listed as an CONTROLS ENCLOSUR SENSOR CONTROLS assembly. **ENCLOSURE** — н Controls mounted as standard on RH side as shown. Terminals ordered with LH controls (optional) are built as mirror image. 34 5/8" (879) HINGÉD HEATER ACCESS PANEL

Voltage:

Single phase, 60 Hz.

□ 120V □ 208V ☐ 240V ☐ 277V

Three phase, 60 Hz.

□ 208V □ 480V (4 wire wye)

☐ 600V (Dual point connection)

Options:

3/4"

(19)

- ☐ Toggle disconnect switch (includes fan).
- Door interlock disconnect switch.
- ☐ Dust tight construction. ☐ Manual reset secondary thermal cut out.

Power circuit fusing.

Unit Size	W	L	Н	IW x IH	K	М	N	EW x EH
2	32 (813)	36 (914)	11 (279)	12 x 10 (305 x 254)	18 1/2 (470)	19 (483)	1 1/2 (38)	10 1/2 x 9 (267 x 229)
3	38 (965)	36 (914)	11 (279)	16 x 10 (406 x 254)	24 1/2 (622)	19 (483)	1 1/2 (38)	16 1/2 x 9 (419 x 229)
4	43 (1092)	36 (914)	12 1/2 (318)	19 x 10 (483 x 254)	27 (686)	22 (559)	3/4 (19)	19 x 10 1/2 (483 x 267)

SCHEDULE TYPE:	Page 2 of 2.			
PROJECT:	Dii	Dimensions are in inches (mm). DATE B SERIES SUPERSEDES DRAW		
ENGINEER:	DATE	B SERIES	SUPERSEDES	DRAWING NO
CONTRACTOR:	6 - 7 - 22	3700	3 - 24 - 17	37N-1