

STAINLESS STEEL DYNAMIC CURTAIN TYPE FIRE DAMPER

1 1/2 HR. LABEL • VERTICAL FOR USE IN DYNAMIC OR STATIC SYSTEMS MODEL: D0120SS (TYPE B)



QUALIFICATIONS:

- UL 555 & CAN/ULC-S112 CLASSIFIED DYNAMIC FIRE DAMPER.
 1 1/2 hr. label (File # R9492).
- Meets all the requirements of UL and NFPA 80, 90A and 101 for fire dampers in dynamic HVAC systems, as well as IBC and NBC (Canada) Building Code requirements.
- City of New York Board of Standards and Appeals. Cal. No. 460-88-SA.
- California State Fire Marshal: Fire Damper Listing No. 3225-0935:0113.
- Maximum velocity: 2000 fpm @ 4" w.g. (10 m/s @ 1 kPa).

Model D0120SS stainless steel curtain fire damper is UL approved for use where local building codes require the protection of HVAC ductwork penetrations in walls or partitions that have a fire resistance rating of up to 2 hours. The D0120SS is classified for use in dynamic "fans on" systems where the HVAC system remains operative in the event of a fire. Damper closure under airflow is assured. Type B fire dampers place the curtain blade pack out of the airstream for higher free area and reduced pressure drop.

STANDARD CONSTRUCTION:

Frame: 4 7/8" (124) wide, 22 ga. (0.79) roll-formed Type 304

stainless steel.

Blades: Curtain type interlocking blades, 22 ga. (0.79)

roll-formed Type 304 stainless steel.

Enclosure: 22 ga. (0.79) stainless steel. **Fusible Link:** 165°F (74°C) standard. UL Listed.

212°F (100°C) available.


Blade Closure: Stainless steel closure springs and stainless steel

locking ramps.

Sizes (Duct W x H):


Velocity/	Single Section		
Pressure	Minimum	Maximum	
Rating	Vertical	Vertical	
24	4" x 4" (102 x 102)	24" x 21" (610 x 533)	


OPTIONS:



DYNAMIC VELOCITY/PRESSURE RATING:

□ 24 2000 fpm @ 4" w.g. (Standard)





MODEL D0120SS - VERTICAL MOUNT

Duct Height H	Dim. A	
4" thru 15" (102 thru 381)	2" (51)	
16" thru 24" (406 thru 610)	3" (76)	

SCHEDULE TYPE:	For installation instructions, see IOM-FDINST.				
PROJECT:	Dimensions are in inches (mm).				
ENGINEER:	DATE	B SERIES	SUPERSEDES	DRAWING NO.	
CONTRACTOR:	10 - 9 - 20	FD	10 - 22 - 18	D0100SS-2	