

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
9 x 6 .375 SQ. FT.	RETURN FACTORS —SP=1.2 TP NC + 0	CFM NC	110 —	150 14	185 20	225 25	260 29	300 33	335 37
	4B	CFM/SIDE THROW, FT.	37 18 7-11-13 5-6-10	50 25 10-12-16 6-7-11	62 31 11-13-18 7-10-12	75 37 12-14-19 7-10-13	87 44 12-16-20 10-11-14	100 50 13-17-22 10-12-15	112 56 14-18-23 11-12-16
	3A1	CFM/SIDE THROW, FT.	47 18 10-11-14 5-6-10	62 25 11-12-17 6-7-11	78 31 12-13-19 7-10-12	94 37 13-14-20 7-10-13	109 44 14-16-22 10-11-14	125 50 14-17-23 10-12-15	140 56 16-18-26 11-12-16
	3A2	CFM/SIDE THROW, FT.	42 35 8-12-14 6-8-13	55 47 10-13-17 8-10-14	70 58 12-14-19 10-12-16	84 70 13-16-21 10-13-17	98 82 13-17-22 12-13-18	112 94 14-18-23 12-14-19	126 105 16-19-25 13-16-21
	2A 2B	CFM/SIDE THROW, FT.	56 11-12-16	75 12-14-19	93 13-16-22	112 14-18-23	131 16-19-24	150 17-20-26	168 18-22-29
	2C 2E	CFM/SIDE THROW, FT.	75 37 12-14-19 8-12-14	100 50 13-16-22 10-13-17	125 62 14-18-25 12-14-19	150 75 16-19-29 13-16-21	175 87 17-21-29 13-17-25	200 100 18-22-31 14-18-23	225 112 20-23-33 16-20-25
	1A 1B	CFM/SIDE THROW, FT.	112 14-17-23	150 17-19-29	187 19-22-31	225 21-23-34	262 22-25-36	300 23-29-39	337 25-29-42
12 x 6 .50 SQ. FT.	RETURN FACTORS —SP=1.6 TP NC + 1	CFM NC	150 —	200 14	250 20	300 26	350 31	400 35	450 39
	4B	CFM/SIDE THROW, FT.	56 18 11-13-17 5-6-10	75 25 12-14-19 6-7-11	94 31 13-17-22 7-10-12	113 37 14-18-23 7-10-13	131 44 16-19-26 10-11-14	150 50 17-20-26 10-11-14	169 56 18-22-29 11-12-16
	3A1	CFM/SIDE THROW, FT.	66 18 11-13-18 5-6-10	87 25 12-14-20 6-7-11	109 31 13-17-23 7-10-12	131 37 14-18-26 7-10-13	153 44 16-19-26 10-11-14	175 50 17-20-29 10-11-14	197 56 18-22-30 11-12-16
	3B	CFM/SIDE THROW, FT.	75 37 11-16-20 8-12-14	100 50 14-18-23 10-13-17	126 62 16-20-27 12-14-19	150 75 18-22-29 13-16-21	176 87 18-23-31 13-17-25	200 100 20-25-32 14-18-23	226 112 22-27-34 16-20-25
	2A 2B	CFM/SIDE THROW, FT.	75 11-13-18	100 12-14-20	125 13-17-23	150 14-18-26	175 16-19-26	200 17-20-29	225 18-22-30
	2C 2E	CFM/SIDE THROW, FT.	112 37 14-17-23 8-12-14	150 50 17-19-29 10-13-17	188 62 19-22-31 12-14-19	225 75 21-23-34 13-16-21	263 87 22-25-36 13-17-25	300 100 23-29-39 14-18-23	338 112 25-29-42 16-20-25
	1A 1B	CFM/SIDE THROW, FT.	150 14-17-23	200 17-19-29	250 19-22-31	300 21-23-34	350 22-25-36	400 23-29-39	450 25-29-42
15 x 6 .625 SQ. FT.	RETURN FACTORS —SP=1.9 TP NC + 1	CFM NC	190 —	250 15	310 21	375 27	440 32	500 36	565 40
	4B	CFM/SIDE THROW, FT.	75 18 11-13-18 5-6-10	100 25 12-14-20 6-7-11	125 31 13-17-23 7-10-12	150 37 14-18-26 7-10-13	175 44 16-19-26 10-11-14	200 50 17-20-29 10-11-14	225 56 18-22-30 11-12-16
	4E	CFM/SIDE THROW, FT.	56 37 11-12-16 10-11-14	75 50 12-14-19 11-12-17	94 62 12-17-22 12-13-19	113 75 14-18-23 13-14-20	131 87 16-19-26 14-16-22	150 100 16-20-26 14-17-23	169 112 18-22-29 16-18-26
	3A1	CFM/SIDE THROW, FT.	84 18 12-13-19 5-6-10	112 25 13-16-22 6-7-11	140 31 14-18-24 7-10-12	169 37 16-19-26 7-10-13	197 44 17-20-28 10-11-14	225 50 18-22-30 10-11-14	253 56 19-23-34 11-12-16
	2A 2B	CFM/SIDE THROW, FT.	94 12-14-20	125 13-16-23	156 14-19-26	187 16-20-28	219 17-22-30	250 18-23-31	281 19-26-35
	2C 2E	CFM/SIDE THROW, FT.	150 37 14-17-23 8-12-14	200 50 17-19-29 10-13-17	250 62 19-22-31 12-14-19	300 75 21-23-34 13-16-21	350 87 22-25-36 13-17-22	400 100 23-29-39 14-18-23	450 112 25-29-42 16-20-25
	1A 1B	CFM/SIDE THROW, FT.	188 16-19-26	250 18-22-30	312 21-25-34	375 22-29-38	438 23-29-40	500 25-31-43	563 29-32-45

Notes:

1. Core style 4E is sized to give equal flow as near as possible in directions A and B.
2. For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: A x .82 = B.

For performance notes, see page D37.

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
18 x 6 .75 SQ. FT.	RETURN FACTORS —SP=2.6 TP NC + 2	CFM NC	225 —	300 16	375 22	450 28	525 33	600 37	675 41
	4B 4C	CFM/SIDE THROW, FT.	A 94 18 B 12-14-20 5-6-10	A 125 25 B 13-17-23 6-7-11	A 156 31 B 14-19-25 7-10-12	A 188 37 B 16-20-28 7-10-13	A 218 44 B 17-22-30 10-11-14	A 250 50 B 18-23-31 10-11-14	A 281 56 B 19-26-35 11-12-16
	4E	CFM/SIDE THROW, FT.	56 56 11-13-17 11-13-17	75 75 12-14-19 12-14-19	94 94 13-17-22 13-17-22	113 113 14-18-23 14-18-23	131 131 16-19-26 16-19-26	150 150 17-20-26 17-20-26	169 169 18-22-29 18-22-29
	3A1	CFM/SIDE THROW, FT.	103 18 12-14-20 5-6-10	137 25 13-17-23 6-7-11	172 31 14-19-25 7-10-12	206 37 16-20-28 7-10-13	240 44 17-22-30 10-11-14	275 50 18-23-31 10-11-14	309 56 19-26-35 11-12-16
	2A 2B	CFM/SIDE THROW, FT.	112 13-16-22	150 16-18-26	187 18-20-29	225 19-22-31	262 20-23-34	300 22-26-36	337 23-26-38
	2C 2E 2D 2F	CFM/SIDE THROW, FT.	187 37 16-19-26 8-12-14	250 50 18-22-30 10-13-17	313 62 21-25-34 12-14-19	375 75 22-29-38 13-16-21	438 87 23-29-40 13-17-22	500 100 25-31-43 14-18-23	563 112 29-32-45 16-19-25
	1A 1B	CFM/SIDE THROW, FT.	225 17-21-29	300 19-23-32	375 22-26-38	450 23-29-42	525 25-30-44	600 29-32-47	675 29-36-52
21 x 6 .875 SQ. FT.	RETURN FACTORS —SP=3.2 TP NC + 3	CFM NC	260 —	350 16	435 22	525 29	610 33	700 38	785 41
	4B 4C	CFM/SIDE THROW, FT.	A 112 18 B 13-16-22 5-6-10	A 150 25 B 16-18-26 6-7-11	A 187 31 B 18-20-29 7-10-12	A 225 37 B 19-22-31 7-10-13	A 262 44 B 20-23-34 10-11-14	A 300 50 B 22-26-36 10-11-14	A 337 56 B 23-26-38 11-12-16
	4E	CFM/SIDE THROW, FT.	75 56 11-13-18 11-13-17	100 75 12-14-20 12-14-19	125 94 13-17-23 13-17-22	150 113 14-18-26 14-18-23	175 131 16-19-26 16-19-26	200 150 17-20-29 17-20-26	225 169 18-22-30 18-22-29
	3A1	CFM/SIDE THROW, FT.	122 18 13-16-22 5-6-10	162 25 16-18-26 6-7-11	203 31 18-20-29 7-10-12	244 37 19-22-31 7-10-13	284 44 20-23-34 10-11-14	325 50 22-26-36 10-11-14	365 56 23-26-38 11-12-16
	2A 2B	CFM/SIDE THROW, FT.	131 13-16-22	175 16-18-26	218 18-20-29	262 19-22-31	306 20-23-34	350 22-26-36	393 23-26-38
	2C 2E 2D 2F	CFM/SIDE THROW, FT.	225 37 17-21-29 8-12-14	300 50 19-23-32 10-13-17	375 62 22-26-38 12-14-19	450 75 23-29-42 13-16-21	525 87 25-30-44 13-17-22	600 100 29-32-47 14-18-23	675 112 29-36-49 16-19-25
	1A 1B	CFM/SIDE THROW, FT.	262 17-21-29	350 19-23-32	437 22-26-38	525 23-29-42	612 25-30-44	700 29-32-47	787 29-36-49
24 x 6 1.0 SQ. FT.	RETURN FACTORS —SP=3.9 TP NC + 4	CFM NC	300 —	400 16	500 23	600 30	700 34	800 39	900 42
	4B 4C	CFM/SIDE THROW, FT.	A 131 18 B 13-16-22 5-6-10	A 175 25 B 16-18-26 6-7-11	A 219 31 B 18-20-29 7-10-12	A 263 37 B 19-22-31 7-10-13	A 306 44 B 20-23-34 10-11-14	A 350 50 B 22-26-36 10-11-14	A 394 56 B 23-26-38 11-12-16
	4E	CFM/SIDE THROW, FT.	75 75 11-13-18 11-13-17	100 100 12-14-20 12-14-20	125 125 13-17-23 13-17-23	150 150 14-18-26 14-18-26	175 175 16-19-26 16-19-26	200 200 17-20-29 17-20-29	225 225 18-22-30 18-22-30
	3A1	CFM/SIDE THROW, FT.	141 18 13-16-22 5-6-10	187 25 16-18-26 6-7-11	234 31 18-20-29 7-10-12	281 37 19-22-31 7-10-13	328 44 20-23-34 10-11-14	375 50 22-26-36 10-11-14	422 56 23-26-38 11-12-16
	2A 2B	CFM/SIDE THROW, FT.	150 13-16-22	200 16-18-26	250 18-20-29	300 19-22-31	350 20-23-34	400 22-26-36	450 23-26-38
	2C 2E 2D 2F	CFM/SIDE THROW, FT.	260 37 17-21-29 8-12-14	350 50 19-23-32 10-13-17	438 62 22-26-38 12-14-19	525 75 23-29-42 13-16-21	613 87 25-30-44 13-17-22	700 100 29-32-47 14-18-23	788 112 29-36-49 16-19-25
	1A 1B	CFM/SIDE THROW, FT.	300 18-22-31	400 21-25-36	500 23-29-42	600 25-30-44	700 29-32-47	800 29-34-51	900 31-38-53

Notes:

1. Core style 4E is sized to give equal flow as near as possible in directions A and B.
2. For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: A x .82 = B.

For performance notes, see page D37.

D

CEILING DIFFUSERS

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
30 x 6 1.25 SQ. FT.	RETURN FACTORS —SP=3.2 TP NC + 3	CFM NC	375 —	500 17	625 24	750 30	875 35	1000 40	1125 43
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	4E	CFM/SIDE THROW, FT.	169 18 16-19-26 5-6-10	225 25 18-22-30 6-8-12	281 31 21-25-34 8-10-13	338 37 22-29-38 8-10-14	393 44 23-29-40 10-12-16	450 50 25-31-43 10-12-16	506 56 27-32-45 12-13-17
	3A1	CFM/SIDE THROW, FT.	94 94 13-16-22 13-16-22	125 125 14-18-25 14-18-25	156 156 16-21-29 16-21-29	188 188 17-22-30 17-22-30	219 219 18-23-32 18-23-32	250 250 19-25-34 19-25-34	282 282 21-29-38 21-29-38
	2A 2B	CFM/SIDE THROW, FT.	178 18 16-19-26 5-6-10	237 25 18-22-30 6-8-12	297 31 21-25-34 8-10-13	356 37 22-29-38 8-10-14	415 44 23-29-40 10-12-16	475 50 25-31-43 10-12-16	534 56 27-32-45 12-13-17
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	187 16-19-26	250 18-22-30	312 21-25-34	375 22-29-38	437 23-29-40	500 25-31-43	562 27-32-45
	1A 1B	CFM/SIDE THROW, FT.	337 37 18-22-31 8-12-14	450 50 21-25-36 10-13-17	563 62 23-29-42 12-14-19	675 75 25-30-44 13-16-21	788 87 27-32-47 13-17-22	900 100 29-34-51 14-18-23	1013 112 31-38-53 16-19-25
12 x 9 .75 SQ. FT.	RETURN FACTORS —SP=3.9 TP NC + 4	CFM NC	225 —	300 17	375 23	450 28	525 33	600 36	675 40
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	3A1	CFM/SIDE THROW, FT.	70 42 10-13-17 6-8-13	94 56 12-14-19 8-10-14	117 70 13-16-22 10-12-16	141 84 14-17-23 10-13-17	164 98 16-18-25 12-13-18	188 112 16-19-27 12-14-19	211 126 17-21-29 13-16-21
	3A2	CFM/SIDE THROW, FT.	91 42 13-16-22 6-8-13	121 56 14-18-25 8-10-14	152 70 16-21-29 10-12-16	183 84 17-22-30 10-13-17	213 98 18-23-32 12-13-18	244 112 19-25-34 12-14-19	274 126 21-29-38 13-16-21
	2A 2B	CFM/SIDE THROW, FT.	75 75 13-15-20 13-15-20	100 100 14-17-22 14-17-22	125 125 15-20-25 15-20-25	150 150 17-21-27 17-21-27	175 175 18-22-31 18-22-31	200 200 20-24-31 20-24-31	225 225 21-25-34 21-25-34
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	112 14-17-23	150 17-19-29	187 19-22-31	225 21-23-34	262 22-25-36	300 23-27-39	337 25-29-42
	1A 1B	CFM/SIDE THROW, FT.	141 84 15-18-25 13-15-20	188 112 18-21-31 14-17-22	234 141 21-24-34 15-20-25	281 169 22-25-36 17-21-27	328 197 24-27-39 18-22-31	375 225 25-29-42 20-24-31	422 253 27-31-45 21-25-34
15 x 9 .93 SQ. FT.	RETURN FACTORS —SP=1.7 TP NC + 3	CFM NC	280 —	375 18	470 24	565 29	655 34	750 37	845 41
	4B 4C	CFM/SIDE THROW, FT.	A B A	B A	B A	B A	B A	B A	B
	4E	CFM/SIDE THROW, FT.	98 42 13-16-22 6-8-13	131 56 14-18-25 8-10-14	165 70 16-21-29 10-12-16	198 84 17-22-30 10-13-17	230 98 18-23-32 12-13-18	263 112 19-25-34 12-14-19	296 126 21-29-38 13-16-21
	3A1	CFM/SIDE THROW, FT.	70 70 12-14-19 12-14-19	94 94 13-16-22 13-16-22	117 117 14-18-25 14-18-25	141 141 16-19-29 16-19-29	164 164 17-21-29 17-21-29	188 188 18-22-31 18-22-31	211 211 19-23-32 19-23-32
	3A2	CFM/SIDE THROW, FT.	120 42 14-17-23 6-8-13	159 56 17-19-29 8-10-14	200 70 19-22-31 10-12-16	240 84 21-23-34 10-13-17	279 98 22-25-36 12-13-18	319 112 23-27-39 12-14-19	359 126 25-29-42 13-16-21
	2A 2B	CFM/SIDE THROW, FT.	117 82 14-15-22 11-14-18	155 110 15-18-25 13-15-21	196 137 17-21-28 14-17-24	233 165 18-22-31 15-18-25	272 192 20-24-32 17-20-27	312 219 21-25-35 17-21-31	351 247 22-27-39 18-22-31
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	140 14-17-23	187 17-19-29	235 19-22-31	281 21-23-34	328 22-25-36	375 23-29-39	422 25-29-42
15 x 9 .93 SQ. FT.	1A 1B	CFM/SIDE THROW, FT.	197 84 17-21-28 13-15-20	263 112 20-24-32 14-17-22	329 141 22-27-36 15-20-25	394 169 24-31-41 17-21-27	459 197 25-31-43 18-22-30	525 225 27-34-46 20-24-32	592 253 31-35-49 21-25-34
	1A 1B	CFM/SIDE THROW, FT.	281 20-24-34	375 22-27-39	470 25-31-45	563 27-32-48	656 29-35-50	750 31-36-55	845 34-41-57

Notes:

- Core style 4E is sized to give equal flow as near as possible in directions A and B.
- For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: $A \times .82 = B$.

For performance notes, see page D37.

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
18 x 9 1.125 SQ. FT.	RETURN FACTORS —SP=2.1 TP NC + 3	CFM NC	335 —	450 19	560 25	675 30	790 35	900 38	1010 42
	4B 4C	CFM/SIDE THROW, FT.	126 42 14-17-23 6-8-13	169 56 17-19-29 8-10-14	211 70 19-22-31 10-12-16	254 84 21-23-34 10-13-17	296 98 22-25-36 12-13-18	338 112 23-27-39 12-14-19	380 126 25-29-42 13-16-21
	4E	CFM/SIDE THROW, FT.	99 70 13-16-22 12-14-19	132 94 14-18-25 13-16-22	164 117 16-21-29 14-18-25	197 141 17-22-30 16-19-29	230 164 18-23-32 17-21-29	263 188 19-25-34 18-22-31	296 211 21-29-38 19-23-32
	3A1	CFM/SIDE THROW, FT.	147 42 14-17-23 6-8-13	197 56 17-19-29 8-10-14	246 70 19-22-31 10-12-16	295 84 21-23-34 10-13-17	345 98 22-25-36 12-13-18	394 112 23-27-39 12-14-19	443 126 25-29-42 13-16-21
	3B	CFM/SIDE THROW, FT.	168 84 17-21-28 13-15-20	225 112 19-23-32 14-17-22	281 141 21-27-36 15-20-25	337 169 23-28-40 17-21-27	394 197 25-30-42 18-22-31	450 225 27-32-46 20-24-31	506 253 28-34-47 21-25-34
	2A 2B	CFM/SIDE THROW, FT.	163 16-19-26	225 18-22-30	281 21-25-34	337 22-29-38	394 23-29-40	450 25-31-43	506 29-32-45
	2C 2E	CFM/SIDE THROW, FT.	253 84 18-22-31 13-15-20	338 112 21-25-35 14-17-22	421 141 24-28-41 15-20-25	506 169 25-31-45 17-21-27	591 197 27-32-48 18-22-31	675 225 29-35-50 20-24-31	759 253 31-39-53 21-25-34
	1A 1B	CFM/SIDE THROW, FT.	337 20-24-34	450 22-27-39	562 25-31-45	675 27-32-48	788 29-35-50	900 31-36-55	1012 34-41-57
	RETURN FACTORS —SP=2.5 TP NC + 4	CFM NC	395 —	525 19	655 25	785 31	915 36	1050 38	1180 42
	4B 4C	CFM/SIDE THROW, FT.	154 42 16-19-26 6-8-13	206 56 18-22-30 8-10-14	258 70 21-25-34 10-12-16	309 84 22-29-38 10-13-17	360 98 23-29-40 12-13-18	413 112 25-31-43 12-14-19	464 126 29-32-45 13-16-21
21 x 9 1.125 SQ. FT.	4E	CFM/SIDE THROW, FT.	98 98 13-16-22 13-16-22	131 131 14-18-25 14-18-25	163 163 16-21-29 16-21-29	196 196 17-22-30 17-22-30	229 229 18-23-32 18-23-32	261 261 19-25-34 19-25-34	294 294 21-29-38 21-29-38
	3A1	CFM/SIDE THROW, FT.	175 42 16-19-26 6-8-13	234 56 18-22-30 8-10-14	292 70 21-25-34 10-12-16	351 84 22-29-38 10-13-17	410 98 23-29-40 12-13-18	468 112 25-31-43 12-14-19	527 126 29-32-45 13-16-21
	2A 2B	CFM/SIDE THROW, FT.	196 16-19-26	262 18-22-30	327 21-25-34	393 22-27-38	458 23-29-40	525 25-31-43	590 29-32-45
	2C 2E	CFM/SIDE THROW, FT.	308 84 20-24-34 13-15-20	412 112 22-27-39 14-17-22	514 141 25-31-45 15-20-25	617 169 27-32-48 17-21-27	720 197 31-35-50 18-22-29	825 225 31-36-55 20-24-31	927 253 34-41-57 21-25-34
	1A 1B	CFM/SIDE THROW, FT.	393 21-25-35	524 24-31-42	655 27-34-48	786 29-36-50	917 31-39-55	1050 34-42-59	1180 35-45-62
	RETURN FACTORS —SP=2.9 TP NC + 4	CFM NC	450 —	600 19	750 25	900 31	1050 36	1200 38	1350 43
	4B 4C	CFM/SIDE THROW, FT.	183 42 17-21-28 7-8-14	244 56 20-24-32 8-11-15	305 70 22-27-36 11-13-17	366 84 24-29-41 11-14-18	427 98 25-31-43 13-14-20	488 112 27-34-46 13-15-21	549 126 31-35-49 14-17-22
	4E	CFM/SIDE THROW, FT.	126 99 15-18-25 14-17-24	169 132 18-21-31 15-20-27	211 164 21-24-34 17-22-31	253 197 22-25-36 18-24-32	295 230 24-27-39 20-25-35	337 263 25-31-42 21-27-36	379 296 27-31-45 22-31-41
	3A1	CFM/SIDE THROW, FT.	204 42 17-21-28 7-8-14	272 56 20-24-32 8-11-15	340 70 22-27-36 11-13-17	408 84 24-29-41 11-14-18	476 98 25-31-43 13-14-20	544 112 27-34-46 13-15-21	612 126 31-35-49 14-17-22
	2A 2B	CFM/SIDE THROW, FT.	225 18-22-31	300 21-25-35	375 24-28-41	450 25-31-45	525 27-32-48	600 29-35-50	675 31-39-53
24 x 9 1.5 SQ. FT.	2C 2E	CFM/SIDE THROW, FT.	365 84 21-25-35 13-15-20	488 112 24-31-42 14-17-22	609 141 27-34-48 15-20-25	731 169 29-36-50 17-21-27	853 197 31-39-55 18-22-29	975 225 34-42-59 20-24-31	1097 253 35-45-62 21-25-34
	1A 1B	CFM/SIDE THROW, FT.	450 21-25-35	600 24-31-42	750 27-34-48	900 29-36-50	1050 31-39-55	1200 34-42-59	1350 35-45-62

Notes:

- Core style 4E is sized to give equal flow as near as possible in directions A and B.
- For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: $A \times .82 = B$.

For performance notes, see page D37.

D

CEILING DIFFUSERS

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
30 x 9 1.875 SQ. FT.	RETURN FACTORS —SP=3.9 TP NC + 5	CFM NC	560 —	750 20	935 26	1125 32	1310 37	1500 39	1685 44
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	4E	CFM/SIDE THROW, FT.	238 42 18-22-31 7-8-14	319 56 21-25-35 8-11-15	398 70 24-28-41 11-13-17	478 84 25-31-45 11-14-18	557 98 27-32-48 13-14-20	638 112 29-35-50 13-15-21	716 126 31-39-53 14-17-22
	3A1	CFM/SIDE THROW, FT.	155 126 17-21-28 15-18-25	206 169 20-24-32 18-21-31	258 211 22-27-36 21-24-34	310 253 24-31-41 22-25-36	361 295 25-31-42 24-27-39	413 337 27-34-46 25-29-42	465 379 31-35-49 27-31-45
	2A 2B	CFM/SIDE THROW, FT.	259 42 18-22-31 7-8-14	347 56 21-25-35 8-11-15	433 70 24-28-41 11-13-17	520 84 25-31-45 11-14-18	606 98 27-32-48 13-14-20	694 112 29-35-50 13-15-21	779 126 31-39-53 14-17-22
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	281 20-24-34	375 22-27-39	468 25-31-45	562 27-32-48	655 29-35-50	750 31-36-55	842 34-41-57
	1A 1B	CFM/SIDE THROW, FT.	476 84 22-27-39 13-15-20	638 112 25-31-45 14-17-22	796 141 28-35-50 15-20-25	956 169 31-39-55 17-21-27	1113 197 32-42-59 18-22-31	1275 225 35-45-62 20-24-31	1432 253 39-48-66 21-25-34
36 x 9 2.25 SQ. FT.	RETURN FACTORS —SP=5.0 TP NC + 6	CFM NC	675 —	900 21	1125 27	1350 33	1575 38	1800 40	2025 44
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	4E	CFM/SIDE THROW, FT.	295 42 20-24-34 7-8-14	394 56 22-27-39 8-11-15	492 70 25-31-45 11-13-17	591 84 27-32-48 11-14-18	689 98 29-35-50 13-14-20	788 112 31-36-55 13-15-21	886 126 34-41-57 14-17-22
	3A1	CFM/SIDE THROW, FT.	183 155 17-21-28 17-21-28	244 206 20-24-32 20-24-32	305 258 22-27-36 22-27-36	366 310 24-31-41 24-31-41	427 361 25-31-42 25-31-42	488 413 27-34-46 27-34-46	549 465 31-35-49 31-35-49
	2A 2B	CFM/SIDE THROW, FT.	316 42 20-24-34 7-8-14	422 56 22-27-39 8-11-15	527 70 25-31-45 11-13-17	633 84 27-32-48 11-14-18	738 98 29-35-50 13-14-20	844 112 31-36-55 13-15-21	949 126 34-41-57 14-17-22
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	337 20-24-34	450 22-27-39	562 25-31-45	675 27-32-48	787 29-35-50	900 31-36-55	1012 34-41-57
	1A 1B	CFM/SIDE THROW, FT.	590 84 24-31-42 13-15-20	788 112 28-34-48 14-17-22	984 141 32-39-55 15-20-25	1181 169 34-42-57 17-21-27	1378 197 36-45-62 18-22-29	1575 225 41-49-66 20-24-31	1772 253 43-52-70 21-25-34
15 x 12 1.25 SQ. FT.	RETURN FACTORS —SP=1.6 TP NC + 2	CFM NC	375 —	500 19	625 25	750 30	875 34	1000 38	1125 41
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	3A1	CFM/SIDE THROW, FT.	112 75 13-15-21 8-13-15	150 100 14-17-24 11-14-18	187 125 15-20-27 13-15-21	225 150 17-21-29 14-17-22	262 175 18-22-31 14-18-24	300 200 20-24-34 15-20-25	337 225 21-25-35 17-21-27
	3A2	CFM/SIDE THROW, FT.	150 75 15-18-25 8-13-15	200 100 18-21-31 11-14-18	250 125 21-24-34 13-15-21	300 150 22-25-36 14-17-22	350 175 24-27-39 14-18-24	400 200 25-29-42 15-20-25	450 225 27-31-45 17-21-27
	2A 2B	CFM/SIDE THROW, FT.	117 129 11-14-18 14-15-22	156 172 13-15-21 15-18-25	195 215 14-17-24 17-21-28	234 258 15-18-25 18-22-31	273 301 17-20-27 20-24-32	312 344 17-21-29 21-25-35	351 387 18-22-31 22-27-39
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	187 17-21-28	250 20-24-32	312 22-27-36	375 24-29-41	437 25-31-43	500 27-34-46	567 31-35-49
	1A 1B	CFM/SIDE THROW, FT.	225 150 18-22-31 14-17-24	300 200 21-25-35 15-20-27	375 250 24-28-41 17-22-31	450 300 25-31-45 18-24-32	525 350 27-32-48 20-25-35	600 400 31-35-50 21-27-36	675 450 31-39-53 22-31-41

Notes:

- Core style 4E is sized to give equal flow as near as possible in directions A and B.
- For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: $A \times .82 = B$.

For performance notes, see page D37.

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
18 x 12 1.5 SQ. FT.	RETURN FACTORS —SP=1.9 TP NC + 3	CFM NC	450 —	600 20	750 26	900 31	1050 35	1200 39	1350 42
		CFM/SIDE THROW, FT.	A 150 75 15-18-25 8-13-15	A 200 100 18-21-31 11-14-18	A 250 125 21-24-34 13-15-21	A 300 150 22-25-36 14-17-22	A 350 175 24-27-39 14-18-24	A 400 200 25-31-42 15-20-25	A 450 225 27-31-45 17-21-27
		CFM/SIDE THROW, FT.	A 187 75 17-21-28 8-13-15	A 250 100 20-24-32 11-14-18	A 312 125 22-27-36 13-15-21	A 375 150 24-31-41 14-17-22	A 437 175 25-31-43 14-18-24	A 500 200 27-34-46 15-20-25	A 562 225 31-35-49 17-21-27
		CFM/SIDE THROW, FT.	A 168 141 14-17-24 13-15-21	A 225 187 15-20-27 14-17-24	A 281 234 17-22-31 15-20-27	A 337 281 18-24-32 17-21-31	A 394 328 20-25-35 18-22-31	A 450 375 21-27-36 20-24-34	A 506 422 22-31-41 21-25-35
		CFM/SIDE THROW, FT.	A 225 18-22-31	A 300 21-25-35	A 375 24-28-41	A 450 25-31-45	A 525 27-32-48	A 600 29-35-50	A 675 31-39-53
		CFM/SIDE THROW, FT.	A 300 150 20-24-34 14-17-24	A 400 200 22-27-39 15-20-27	A 500 250 25-31-45 17-22-31	A 600 300 27-32-48 18-24-32	A 700 350 29-35-50 20-25-35	A 800 400 31-36-55 21-27-36	A 900 450 34-41-57 22-31-41
		CFM/SIDE THROW, FT.	A 450 21-25-35	A 600 24-31-42	A 750 27-34-48	A 900 29-36-50	A 1050 31-39-55	A 1200 34-42-59	A 1350 35-45-62
21 x 12 1.75 SQ. FT.	RETURN FACTORS —SP=2.2 TP NC + 5	CFM NC	525 —	700 20	875 26	1050 31	1225 35	1400 39	1575 42
		CFM/SIDE THROW, FT.	A 187 75 17-21-28 8-13-15	A 250 100 20-24-32 11-14-18	A 312 125 22-27-36 13-15-21	A 375 150 24-31-41 14-17-22	A 437 175 25-32-43 14-18-24	A 500 200 27-34-46 15-20-25	A 562 225 31-35-49 17-21-27
		CFM/SIDE THROW, FT.	A 150 112 15-18-25	A 200 150 18-21-31 15-18-25	A 250 187 21-24-34	A 300 225 22-25-36	A 350 262 24-27-39	A 400 300 25-31-42 22-25-36	A 450 337 27-31-45
		CFM/SIDE THROW, FT.	A 225 75 18-22-31 8-13-15	A 300 100 21-25-35 11-14-18	A 375 125 24-28-41 13-15-21	A 450 150 25-31-45 14-17-22	A 525 175 27-32-48 14-18-24	A 600 200 29-35-50 15-20-25	A 675 225 31-39-53 17-21-27
		CFM/SIDE THROW, FT.	A 230 148 14-17-24 13-15-21	A 306 197 15-20-27 14-17-24	A 382 246 17-22-31 15-20-27	A 460 295 18-24-32 17-21-31	A 535 345 20-25-35 18-22-31	A 612 394 21-27-36 20-24-34	A 688 443 22-31-41 21-25-35
		CFM/SIDE THROW, FT.	A 262 18-22-31	A 350 21-25-35	A 437 24-28-41	A 525 25-31-45	A 612 27-32-48	A 700 29-35-50	A 787 31-39-53
		CFM/SIDE THROW, FT.	A 375 150 21-25-35 14-17-24	A 500 200 24-31-42 15-20-27	A 625 250 27-34-48 17-22-31	A 750 300 29-36-50 18-24-32	A 875 350 31-39-55 20-25-35	A 1000 400 34-42-59 21-27-36	A 1125 450 35-45-62 22-31-41
		CFM/SIDE THROW, FT.	A 525 22-27-39	A 700 25-31-45	A 875 28-35-50	A 1050 31-39-55	A 1225 32-42-59	A 1400 35-45-62	A 1575 39-48-66
24 x 12 2.0 SQ. FT.	RETURN FACTORS —SP=2.6 TP NC + 5	CFM NC	600 12	800 21	1000 27	1200 32	1400 36	1600 40	1800 43
		CFM/SIDE THROW, FT.	A 225 75 18-22-31 8-13-15	A 300 100 21-25-35 11-14-18	A 375 125 24-28-41 13-15-21	A 450 150 25-31-45 14-17-22	A 525 175 27-32-48 14-18-24	A 600 200 31-35-50 15-20-25	A 675 225 31-39-53 17-21-27
		CFM/SIDE THROW, FT.	A 150 150 15-18-25 15-18-25	A 200 200 18-21-31 18-21-31	A 250 250 21-24-34 21-24-34	A 300 300 22-25-36 22-25-36	A 350 350 24-27-39 24-27-39	A 400 400 25-31-42 25-31-42	A 450 450 27-31-45 27-31-45
		CFM/SIDE THROW, FT.	A 262 75 18-22-31 8-13-15	A 350 100 21-25-35 11-14-18	A 437 175 24-28-41 13-15-21	A 525 150 25-31-45 14-17-22	A 612 175 27-32-48 14-18-24	A 700 200 29-35-50 15-20-25	A 787 225 31-39-53 17-21-27
		CFM/SIDE THROW, FT.	A 300 150 15-18-25 14-17-24	A 400 200 18-21-31 15-20-27	A 500 250 21-24-34 17-22-31	A 600 300 22-25-36 18-24-32	A 700 350 24-27-39 20-25-35	A 800 400 25-31-42 21-27-36	A 900 450 27-31-45 22-31-41
		CFM/SIDE THROW, FT.	A 300 20-24-34	A 400 22-27-39	A 500 25-31-45	A 600 27-32-48	A 700 29-35-50	A 800 31-36-55	A 900 34-41-57
		CFM/SIDE THROW, FT.	A 450 150 21-25-35 14-17-24	A 600 200 24-31-42 15-20-27	A 750 250 27-34-48 17-22-31	A 900 300 29-36-50 18-24-32	A 1050 350 31-39-55 20-25-35	A 1200 400 34-42-59 21-27-36	A 1350 450 35-45-62 22-31-41
		CFM/SIDE THROW, FT.	A 600 24-31-42	A 800 28-34-48	A 1000 32-39-55	A 1200 34-42-57	A 1400 36-45-62	A 1600 41-49-66	A 1800 43-52-70

Notes:

- Core style 4E is sized to give equal flow as near as possible in directions A and B.
- For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: A x .82 = B.

For performance notes, see page D37.

D

CEILING DIFFUSERS

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
30 x 12 2.5 SQ. FT.	RETURN FACTORS —SP=3.3 TP NC + 6	CFM NC	750 15	1000 23	1250 29	1500 33	1750 37	2000 41	2250 43
	4B 4C	CFM/SIDE THROW, FT.	300 75 20-24-34 8-13-15	400 100 22-27-39 11-14-18	500 125 25-31-45 13-15-21	600 150 27-32-48 14-17-22	700 175 29-35-50 14-18-24	800 200 31-36-55 15-20-25	900 225 34-41-57 17-21-27
	4E	CFM/SIDE THROW, FT.	183 183 17-21-28 17-21-28	250 250 20-24-32 20-24-32	313 313 22-27-36 22-27-36	375 375 24-31-41 24-31-41	437 437 25-31-43 25-31-43	500 500 27-34-46 27-34-46	562 562 31-35-49 31-35-49
	3A1	CFM/SIDE THROW, FT.	337 75 20-24-34 8-13-15	450 100 22-27-39 11-14-18	562 125 25-31-45 13-15-21	675 150 27-32-48 14-17-22	787 175 29-35-50 14-18-24	900 200 31-36-55 15-20-25	1012 225 34-41-57 17-21-27
	2A 2B	CFM/SIDE THROW, FT.	375 21-25-35	500 24-31-42	625 27-34-48	750 29-36-50	875 31-39-55	1000 34-42-59	1125 35-45-62
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	600 150 24-31-41 14-17-24	800 200 28-34-48 15-20-27	1000 250 32-39-55 17-22-31	1200 300 34-42-57 18-24-32	1400 350 36-45-62 20-25-35	1600 400 41-49-66 21-27-36	1800 450 43-52-70 22-31-41
	1A 1B	CFM/SIDE THROW, FT.	750 25-31-45	1000 31-35-50	1250 34-41-57	1500 36-45-62	1750 39-48-66	2000 42-50-70	2250 45-53-74
	RETURN FACTORS —SP=4.0 TP NC + 7	CFM NC	900 16	1200 25	1500 30	1800 34	2100 38	2400 42	2700 44
	4B 4C	CFM/SIDE THROW, FT.	375 75 21-25-35 8-13-15	500 100 24-31-42 11-14-18	625 125 27-34-48 13-15-21	750 150 29-36-50 14-17-22	875 175 31-39-55 14-18-24	1000 200 34-42-59 15-20-25	1125 225 35-45-62 17-21-27
	4E	CFM/SIDE THROW, FT.	225 225 18-22-31 18-22-31	300 300 21-25-35 21-25-35	375 375 24-28-41 24-28-41	450 450 25-31-45 25-31-45	525 525 27-32-48 27-32-48	600 600 29-35-50 29-35-50	675 675 31-39-53 31-39-53
36 x 12 3.0 SQ. FT.	3A1	CFM/SIDE THROW, FT.	412 75 21-25-35 8-13-15	550 100 24-31-42 11-14-18	687 125 27-34-48 13-15-21	825 150 29-36-50 14-17-22	962 175 31-39-55 14-18-24	1100 200 34-42-59 15-20-25	1237 225 35-45-62 17-21-27
	2A 2B	CFM/SIDE THROW, FT.	450 21-25-35	600 24-31-42	750 27-34-48	900 29-36-50	1050 31-39-55	1200 34-42-59	1350 35-45-62
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	750 150 25-31-45 14-17-24	1000 200 31-35-50 15-20-27	1250 250 34-41-57 17-22-31	1500 300 36-45-62 18-24-32	1750 350 39-48-66 20-25-35	2000 400 42-50-70 21-27-36	2250 450 45-53-74 22-31-41
	1A 1B	CFM/SIDE THROW, FT.	900 27-34-46	1200 31-39-53	1500 35-45-60	1800 39-48-64	2100 42-50-70	2400 45-55-74	2700 48-57-80
	RETURN FACTORS —SP=2.0 TP NC + 4	CFM NC	560 14	750 21	935 28	1125 32	1310 36	1500 39	1685 43
	4B 4C	CFM/SIDE THROW, FT.	164 117 14-17-24 11-14-18	219 156 15-20-27 13-15-21	273 195 17-22-31 14-17-24	328 234 18-24-32 15-18-25	383 273 20-25-35 17-20-27	438 312 21-27-36 17-21-31	492 351 22-31-41 18-22-31
	3A1	CFM/SIDE THROW, FT.	222 117 18-22-31 11-14-18	297 156 21-25-35 13-15-21	371 195 24-28-41 14-17-24	445 234 25-31-45 15-18-25	519 273 31-39-55 17-20-27	594 312 31-35-50 17-21-31	668 351 31-39-53 18-22-31
	3A2	CFM/SIDE THROW, FT.	168 197 13-16-22 18-22-30	225 262 15-18-25 21-25-34	281 328 16-21-28 24-28-39	337 394 18-22-33 25-33-43	394 459 19-24-33 27-33-46	450 525 21-25-36 28-36-49	506 590 22-27-37 33-37-52
	2A 2B	CFM/SIDE THROW, FT.	281 20-24-34	375 22-27-39	468 25-31-45	562 27-32-48	656 29-35-50	750 31-36-55	843 34-41-57
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	329 234 25-33-45 18-22-30	438 312 30-36-51 21-25-34	547 390 34-42-58 24-28-39	657 468 36-45-61 25-31-43	766 546 39-48-66 27-33-46	876 624 43-52-70 28-36-49	985 702 46-55-75 33-37-52
	1A 1B	CFM/SIDE THROW, FT.	562 24-28-42	750 27-33-48	937 30-37-54	1125 33-42-58	1312 34-45-63	1500 37-48-66	1687 42-51-70

Notes:

1. Core style 4E is sized to give equal flow as near as possible in directions A and B.
2. For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: A x .82 = B.

For performance notes, see page D37.

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
21 x 15 2.185 SQ. FT.	RETURN FACTORS —SP=2.1 TP NC + 5	CFM NC	655 14	875 21	1090 28	1310 33	1530 36	1750 39	1970 43
	4B 4C	CFM/SIDE THROW, FT.	210 117 19-24-33 12-15-19	281 156 22-27-37 13-16-22	361 195 25-30-43 15-18-25	422 234 27-33-48 16-19-27	493 273 28-34-51 18-21-28	563 312 33-37-54 18-22-33	634 351 33-42-57 19-24-33
	4E	CFM/SIDE THROW, FT.	164 164 18-22-30 18-22-30	218 218 21-25-36 21-25-36	273 273 24-28-39 24-28-39	327 327 25-31-43 25-31-43	382 382 27-33-46 27-33-46	437 437 28-36-49 28-36-49	491 491 33-37-52 33-37-52
	3A1	CFM/SIDE THROW, FT.	269 117 19-24-33 12-15-19	359 156 22-27-37 13-16-22	448 195 25-30-43 15-18-25	539 234 27-33-48 16-19-27	629 273 28-34-51 18-21-28	719 312 33-37-54 18-22-33	809 351 33-42-57 19-24-33
	3A2	CFM/SIDE THROW, FT.	230 213 16-19-27 15-18-25	306 284 19-22-33 16-21-28	382 355 22-25-36 18-24-33	460 426 24-27-39 19-25-34	535 498 25-28-42 21-27-37	612 569 27-31-45 22-28-39	688 641 28-33-48 24-33-43
	2A 2B	CFM/SIDE THROW, FT.	327 21-25-36	437 24-28-42	596 27-33-48	656 28-34-51	766 31-37-54	875 33-39-58	985 36-43-61
	2C 2E 2D 2F	CFM/SIDE THROW, FT.	422 234 22-27-37 18-22-30	563 312 25-33-45 21-25-34	702 390 28-36-51 24-28-39	844 468 29-39-54 25-33-43	966 546 33-42-58 27-33-46	1126 624 36-45-63 28-36-49	1268 702 37-48-66 33-37-52
	1A 1B	CFM/SIDE THROW, FT.	655 25-33-45	875 30-36-51	1092 33-42-58	1312 36-45-61	1532 39-48-66	1750 43-52-70	1970 46-55-75
	RETURN FACTORS —SP=2.6 TP NC + 6	CFM NC	750 14	1000 22	1250 29	1500 34	1750 37	2000 39	2250 44
	4B 4C	CFM/SIDE THROW, FT.	258 117 19-24-33 12-15-19	344 156 22-27-37 13-16-22	430 195 25-30-43 15-18-25	516 234 27-33-48 16-19-27	602 273 28-34-51 18-21-28	688 312 31-37-54 18-22-31	774 351 33-42-57 19-24-33
24 x 15 2.5 SQ. FT.	4E	CFM/SIDE THROW, FT.	164 211 18-22-30 19-24-33	218 281 21-25-36 22-27-37	273 352 24-28-39 25-30-43	327 422 25-31-43 27-33-48	382 492 27-33-46 28-34-51	437 563 28-36-49 33-37-54	491 633 33-37-52 33-42-57
	3A1	CFM/SIDE THROW, FT.	316 117 21-25-36 12-15-19	422 156 24-28-42 13-16-22	527 195 27-33-48 15-18-25	633 234 28-34-51 16-19-27	738 273 31-37-54 18-21-28	844 312 33-39-58 18-22-31	949 351 36-43-61 19-24-33
	3A2	CFM/SIDE THROW, FT.	300 225 19-24-33 16-19-27	400 300 22-27-37 19-22-33	500 375 25-30-43 22-25-36	600 450 27-33-48 24-27-39	700 525 28-34-51 25-28-42	800 600 31-37-54 27-33-45	900 675 33-42-57 28-33-48
	2A 2B	CFM/SIDE THROW, FT.	375 22-27-37	500 25-33-45	625 28-36-51	750 31-39-54	875 33-42-58	1000 36-45-63	1125 37-48-66
	2C 2E 2D 2F	CFM/SIDE THROW, FT.	516 234 24-28-42 18-22-30	688 312 27-33-48 21-25-34	860 390 30-37-54 24-28-39	1032 468 33-42-58 25-31-43	1204 546 34-45-63 27-33-46	1376 624 37-48-66 28-36-49	1548 702 42-51-70 33-37-52
	1A 1B	CFM/SIDE THROW, FT.	750 27-33-48	1000 33-37-54	1250 36-43-61	1500 39-48-66	1750 41-51-70	2000 45-54-75	2250 48-57-79
	RETURN FACTORS —SP=3.1 TP NC + 7	CFM NC	935 14	1250 23	1565 30	1875 36	2190 39	2500 40	2810 45
	4B 4C	CFM/SIDE THROW, FT.	351 117 20-24-34 11-14-18	469 156 22-27-39 13-15-21	587 195 25-31-45 14-17-24	703 234 27-32-48 15-18-25	822 273 29-35-50 17-20-27	938 312 31-36-55 17-21-29	1054 351 34-41-57 18-22-31
	4E	CFM/SIDE THROW, FT.	258 211 18-22-31 18-22-31	344 281 21-25-31 21-25-35	430 352 24-28-41 24-28-41	516 422 25-31-45 25-31-45	602 492 27-32-48 27-32-48	688 583 31-35-50 31-35-50	775 633 31-39-53 31-39-53
	3A1	CFM/SIDE THROW, FT.	410 117 21-25-35 11-14-18	547 156 24-31-42 13-15-21	685 195 27-34-48 14-17-24	820 234 29-36-50 15-18-25	958 273 31-39-55 17-20-27	1094 312 34-42-59 17-21-29	1224 351 35-45-62 18-22-31
30 x 15 3.125 SQ. FT.	3B	CFM/SIDE THROW, FT.	468 234 24-30-40 18-22-30	625 312 28-34-46 21-25-34	782 391 32-38-52 24-28-39	937 469 34-44-58 25-33-43	1095 547 36-44-62 27-33-46	1250 625 38-48-66 28-36-49	1406 702 44-50-70 33-37-52
	2A 2B	CFM/SIDE THROW, FT.	468 22-27-39	625 25-31-45	782 28-35-50	937 31-39-55	1095 32-42-59	1250 35-45-62	1405 39-48-66
	2C 2E 2D 2F	CFM/SIDE THROW, FT.	702 234 25-33-45 18-22-30	938 312 30-36-51 21-25-34	1175 390 34-42-58 24-28-39	1407 468 36-45-61 25-33-43	1644 546 39-48-66 27-33-46	1876 624 43-52-70 28-36-49	2108 702 51-55-75 33-37-52
	1A 1B	CFM/SIDE THROW, FT.	937 28-36-49	1250 33-42-57	1565 37-48-64	1875 42-51-69	2190 45-54-75	2500 48-58-79	2810 51-61-85

Notes:

- Core style 4E is sized to give equal flow as near as possible in directions A and B.
- For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: $A \times .82 = B$.

For performance notes, see page D37.

D

CEILING DIFFUSERS

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
36 x 15 3.75 SQ. FT.	RETURN FACTORS —SP=3.8 TP NC + 7	CFM NC	1125 13	1500 23	1875 31	2250 37	2625 40	3000 41	3375 46
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	4E	CFM/SIDE THROW, FT.	446 117 22-27-37 12-15-19	594 156 25-33-45 13-16-22	742 195 28-36-51 15-18-25	891 234 33-39-54 16-19-27	1039 273 33-45-58 18-21-28	1188 312 36-45-63 18-22-30	1336 351 37-48-66 19-24-33
	3A1	CFM/SIDE THROW, FT.	306 258 21-25-36 19-24-33	408 344 24-28-42 22-27-37	510 430 27-33-48 25-30-43	612 516 28-34-51 27-33-48	714 602 33-37-54 28-34-51	816 688 33-39-58 33-37-54	918 775 36-43-61 33-42-57
	2A 2B	CFM/SIDE THROW, FT.	504 117 24-28-42 12-15-19	672 156 27-33-48 13-16-22	840 195 30-37-54 15-18-25	1008 234 33-45-58 16-19-27	1176 273 34-45-63 18-21-28	1344 312 37-48-66 18-22-30	1512 351 42-51-70 19-24-33
	2C 2D 2E	CFM/SIDE THROW, FT.	562 24-28-42	750 27-33-48	937 30-37-54	1125 33-42-58	1312 34-45-63	1500 37-48-66	1682 42-51-70
	1A 1B	CFM/SIDE THROW, FT.	890 234 28-36-49 18-22-30	1188 312 33-42-49 21-25-34	1485 390 37-48-64 24-28-39	1782 468 42-51-69 25-33-43	2079 546 45-54-75 27-33-46	2376 624 48-58-79 28-36-49	2873 702 51-61-85 33-37-52
			1125 30-37-52	1500 34-43-60	1875 39-48-67	2250 42-52-73	2625 46-57-78	3000 49-60-85	3375 52-64-90
21 x 18 2.625 SQ. FT.	RETURN FACTORS —SP=2.2 TP NC + 5	CFM NC	785 14	1050 21	1310 27	1575 32	1840 36	2100 40	2360 43
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	3A1	CFM/SIDE THROW, FT.	225 169 16-19-27 13-16-22	300 225 19-22-33 15-18-25	375 280 22-25-36 16-21-28	450 337 24-27-40 18-22-30	526 394 25-28-42 19-24-33	600 450 27-33-45 21-25-36	674 506 28-33-48 22-27-37
	3A2	CFM/SIDE THROW, FT.	309 169 21-25-36 13-16-22	412 225 24-28-42 15-18-25	514 281 27-33-48 16-21-28	619 337 28-34-51 18-22-30	723 394 33-37-54 19-24-33	825 450 33-39-58 21-25-36	927 506 36-43-61 22-27-37
	2A 2B	CFM/SIDE THROW, FT.	279 230 21-25-36 15-18-25	372 306 24-28-42 16-21-28	464 382 27-33-48 18-24-33	557 460 28-34-51 19-25-34	652 535 33-37-54 21-27-37	744 612 33-39-58 22-28-39	836 688 36-43-61 24-33-43
	2C 2D 2E	CFM/SIDE THROW, FT.	393 22-27-37	525 25-33-42	655 28-36-46	787 30-39-54	920 33-42-58	1050 36-45-63	1180 37-48-66
	1A 1B	CFM/SIDE THROW, FT.	450 338 22-27-37 19-24-33	600 450 25-33-42 22-27-37	750 560 28-36-46 25-30-43	900 675 30-39-54 27-33-48	1060 790 33-42-58 28-34-51	1200 900 36-45-63 33-37-54	1350 1010 37-48-66 33-42-57
			787 29-35-51	1050 35-40-58	1310 38-46-66	1575 42-51-70	1840 45-54-75	2100 48-58-80	2360 51-61-85
24 x 18 3.0 SQ. FT.	RETURN FACTORS —SP=2.5 TP NC + 6	CFM NC	900 15	1200 22	1500 28	1800 33	2100 37	2400 40	2700 43
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	4E	CFM/SIDE THROW, FT.	281 169 22-27-38 14-18-24	375 225 26-30-45 16-19-27	469 281 29-35-51 18-22-30	563 337 30-37-54 19-24-33	656 394 33-40-58 21-26-35	750 450 35-42-62 22-27-38	844 506 38-46-66 24-29-40
	3A1	CFM/SIDE THROW, FT.	225 225 21-26-35 21-26-35	300 300 24-29-40 24-29-40	375 375 27-32-46 27-32-46	450 450 29-35-51 29-35-51	525 525 30-37-54 30-37-54	600 600 33-40-58 33-40-58	675 675 35-45-61 35-45-61
	3A2	CFM/SIDE THROW, FT.	366 169 24-29-40 14-18-24	487 225 27-35-48 16-19-27	609 281 30-38-54 18-22-30	731 337 35-42-58 19-24-33	853 394 35-45-62 21-26-35	975 450 38-48-67 22-27-38	1098 506 40-51-70 24-29-40
	2A 2B	CFM/SIDE THROW, FT.	300 300 25-31-43 20-23-32	400 400 29-34-50 23-27-40	500 500 32-40-58 27-31-43	600 600 34-41-61 29-32-47	700 700 40-45-65 31-34-50	800 800 40-47-70 32-40-54	900 900 43-52-74 34-40-58
	2C 2D 2E	CFM/SIDE THROW, FT.	450 24-29-40	600 27-35-48	750 30-38-54	900 35-42-58	1050 35-45-62	1200 38-48-67	1350 40-51-70
	1A 1B	CFM/SIDE THROW, FT.	562 338 26-30-45 21-26-35	750 450 29-35-51 24-29-40	938 562 32-40-58 27-32-46	1125 675 35-45-62 29-35-51	1313 787 37-48-67 30-37-54	1500 900 40-51-70 33-40-58	1688 1012 45-54-75 35-45-61
			900 30-38-53	1200 35-45-61	1500 40-51-69	1800 45-54-74	2100 48-58-80	2400 51-62-85	2700 54-66-91

Notes:

- Core style 4E is sized to give equal flow as near as possible in directions A and B.
- For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: $A \times .82 = B$.

For performance notes, see page D37.

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
30 x 18 3.75 SQ. FT.	RETURN FACTORS —SP=3.1 TP NC + 7	CFM NC	1125 15	1500 23	1875 29	2250 34	2625 38	3000 42	3375 45
	4B 4C	CFM/SIDE THROW, FT.	394 169 24-29-40 14-18-24	525 225 27-35-48 16-19-27	657 281 30-38-54 18-22-30	788 337 35-42-58 19-24-35	918 394 35-45-62 21-26-35	1050 450 38-48-67 22-27-38	1181 506 40-51-70 24-29-40
	4E	CFM/SIDE THROW, FT.	281 281 22-27-38 22-27-38	375 375 26-30-45 26-30-45	469 469 29-35-51 29-35-51	563 563 30-37-54 30-37-54	657 657 32-40-58 32-40-58	750 750 35-42-62 35-42-62	845 845 38-46-66 38-46-66
	3A1	CFM/SIDE THROW, FT.	478 169 26-30-45 14-18-24	637 225 29-35-51 16-19-27	797 281 32-40-58 18-22-30	956 337 35-45-62 19-24-35	1115 394 37-48-67 21-26-35	1275 450 40-51-70 22-27-38	1434 506 45-54-75 24-29-40
	3A2	CFM/SIDE THROW, FT.	469 327 22-27-38 19-24-32	625 437 26-30-45 22-27-37	782 546 29-35-51 26-30-42	937 656 30-37-54 27-35-46	1093 766 32-40-58 29-35-50	1250 875 35-42-62 30-38-53	1406 984 38-46-66 35-40-56
	2A 2B	CFM/SIDE THROW, FT.	562 26-30-45	750 29-35-51	937 32-40-58	1125 35-45-62	1312 37-48-67	1500 40-51-70	1687 45-54-75
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	787 337 29-35-51 21-26-35	1050 450 35-40-58 24-29-40	1313 562 38-46-66 27-32-46	1575 675 42-51-70 29-35-51	1838 787 45-54-75 30-37-54	2100 900 48-58-80 33-40-58	2363 1012 51-61-85 35-45-61
	1A 1B	CFM/SIDE THROW, FT.	1125 32-40-56	1500 37-46-62	1875 42-53-72	2250 46-56-78	2625 50-61-83	3000 53-64-91	3375 56-69-96
	RETURN FACTORS —SP=3.6 TP NC + 8	CFM NC	1350 16	1800 24	2250 30	2700 35	3150 39	3600 42	4050 45
	4B 4C	CFM/SIDE THROW, FT.	506 169 26-30-45 14-18-24	675 225 29-35-51 16-19-27	844 281 33-40-58 18-22-30	1013 337 35-45-62 19-24-35	1181 394 37-48-67 21-26-35	1350 450 40-51-70 22-27-38	1519 506 45-54-75 24-29-40
36 x 18 4.5 SQ. FT.	4E	CFM/SIDE THROW, FT.	339 339 22-27-38 22-27-38	452 452 26-30-45 26-30-45	565 565 29-35-51 29-35-51	678 678 30-37-54 30-37-54	791 791 33-40-58 33-40-58	904 904 35-42-62 35-42-62	1020 1020 38-46-66 38-46-66
	3A1	CFM/SIDE THROW, FT.	591 169 27-35-48 14-18-24	787 225 32-38-54 16-19-27	984 281 37-45-62 18-22-30	1181 337 38-48-66 19-24-35	1378 394 42-51-70 21-26-35	1575 450 46-56-75 22-27-38	1772 506 50-59-80 24-29-40
	3B	CFM/SIDE THROW, FT.	675 337 27-35-48 21-26-35	900 450 32-38-54 24-29-40	1125 562 37-45-62 27-32-46	1350 675 38-48-66 29-35-51	1575 787 42-51-70 30-37-54	1800 900 46-56-75 33-40-58	2025 1012 50-59-80 35-45-61
	2A 2B	CFM/SIDE THROW, FT.	675 27-35-48	900 32-38-54	1125 37-45-62	1350 38-48-66	1575 42-51-70	1800 46-56-75	2025 50-59-80
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	1010 337 32-40-56 21-26-35	1350 450 37-46-64 24-29-40	1688 562 42-53-72 27-32-46	2025 675 46-56-78 29-35-51	2363 787 50-61-83 30-37-54	2700 900 53-64-91 33-40-58	3038 1012 56-69-96 35-45-61
	1A 1B	CFM/SIDE THROW, FT.	1350 35-40-59	1800 38-48-67	2250 45-54-77	2700 48-58-82	3150 51-62-90	3600 54-67-93	4050 59-70-101
	RETURN FACTORS —SP=2.1 TP NC + 7	CFM NC	1050 15	1400 22	1750 28	2100 33	2450 37	2800 41	3150 44
	4B 4C	CFM/SIDE THROW, FT.	295 230 20-25-34 17-20-29	394 306 24-29-39 19-24-32	493 382 27-32-44 20-27-37	590 460 29-37-49 22-29-39	690 535 31-37-53 24-31-42	788 612 32-41-56 25-32-44	887 688 37-42-59 27-37-49
	3A1	CFM/SIDE THROW, FT.	410 230 25-31-42 17-20-29	547 306 29-37-51 19-24-32	684 382 32-41-58 20-27-37	820 460 37-44-61 22-29-39	957 535 37-48-66 24-31-42	1094 612 41-51-71 25-32-44	1231 688 42-54-75 27-37-49
	3A2	CFM/SIDE THROW, FT.	375 300 25-31-42 19-22-31	500 400 29-37-51 22-25-37	625 500 32-41-58 25-29-41	750 600 37-44-61 27-31-44	875 700 37-48-66 29-32-48	1000 800 41-51-71 31-37-51	1125 900 42-54-75 32-37-54
24 x 21 3.5 SQ. FT.	2A 2B	CFM/SIDE THROW, FT.	525 27-32-48	700 31-37-54	875 34-42-61	1050 37-48-66	1225 39-51-71	1400 42-54-75	1575 48-58-80
	2C 2D 2E 2F	CFM/SIDE THROW, FT.	591 459 29-37-51 24-29-41	788 612 34-41-58 27-32-48	986 764 39-48-66 31-37-54	1180 920 41-51-70 32-39-58	1380 1070 44-54-75 37-42-61	1576 1224 49-59-80 37-44-66	1774 1376 53-63-85 41-49-70
	1A 1B	CFM/SIDE THROW, FT.	1050 34-42-59	1400 39-49-68	1750 44-56-76	2100 49-59-83	2450 53-65-88	2800 56-68-87	3150 59-73-102

Notes:

- Core style 4E is sized to give equal flow as near as possible in directions A and B.
- For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: $A \times .82 = B$.

For performance notes, see page D37.

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
30 x 21 4.375 SQ. FT.	RETURN FACTORS —SP=3.1 TP NC + 8	CFM NC	1310 16	1750 23	2185 29	2625 34	3060 38	3500 41	3935 44
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	4E	CFM/SIDE THROW, FT.	425 230 25-31-42 17-20-29	569 306 24-37-51 19-24-32	710 382 32-41-58 20-27-37	852 460 37-44-61 22-29-39	995 535 37-48-66 24-31-42	1138 612 41-51-71 25-32-44	1279 688 42-54-75 27-37-49
	3A1	CFM/SIDE THROW, FT.	360 295 24-29-41	480 394 27-32-48	600 492 31-37-54	720 591 32-39-58	840 690 37-42-61	960 788 37-44-66	1080 887 41-49-70
	3A2	CFM/SIDE THROW, FT.	540 230 27-32-48 17-20-29	722 306 31-37-54 19-24-32	901 382 34-42-61 20-27-37	1082 460 37-48-66 22-29-39	1262 535 39-51-71 24-31-42	1444 612 42-54-75 25-32-44	1623 688 48-58-80 27-37-49
	2A 2B	CFM/SIDE THROW, FT.	468 422 25-31-42 20-25-34	625 562 29-37-51 24-29-39	782 701 32-41-58 27-32-44	937 844 37-44-61 29-37-49	1093 983 37-48-66 31-37-53	1250 1125 41-51-71 32-41-56	1406 1264 42-54-75 37-42-61
	2C 2D 2E	CFM/SIDE THROW, FT.	655 29-37-51	875 34-41-58	1092 39-48-66	1312 41-51-70	1530 44-54-75	1750 49-59-80	1968 53-63-85
	1A 1B	CFM/SIDE THROW, FT.	853 457 31-37-54 24-29-41	1138 612 37-42-61 27-32-48	1421 764 41-49-70 31-37-54	1705 920 44-54-75 32-39-58	1990 1070 48-58-80 37-42-61	2276 1224 51-61-85 37-44-66	2559 1376 54-65-90 41-49-70
		CFM/SIDE THROW, FT.	1310 37-42-63	1750 41-51-71	2185 48-58-82	2625 51-61-87	3060 54-66-95	3500 58-71-99	3935 63-75-107
36 x 21 5.25 SQ. FT.	RETURN FACTORS —SP=3.4 TP NC + 8	CFM NC	1575 16	2100 24	2625 30	3150 34	3675 38	4200 42	4725 45
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	4E	CFM/SIDE THROW, FT.	558 230 27-32-48 17-20-29	744 306 31-37-54 19-24-32	930 382 34-42-61 20-27-37	1115 460 37-48-66 22-29-39	1306 535 39-51-71 24-31-42	1488 612 42-54-75 25-32-44	1674 688 48-58-80 27-37-49
	3A1	CFM/SIDE THROW, FT.	427 360 25-31-42 25-31-42	568 480 29-37-61 29-37-51	710 600 32-41-58 32-41-58	852 720 37-44-61 37-44-61	945 840 37-48-66 37-48-66	1135 960 41-51-71 41-51-71	1280 1080 42-54-75 42-54-75
	3A2	CFM/SIDE THROW, FT.	672 230 29-37-51 17-20-29	897 306 34-41-58 19-24-32	1121 382 39-48-66 20-27-37	1345 460 41-51-70 22-29-39	1570 535 44-54-75 24-31-42	1794 612 49-59-80 25-32-44	2018 688 53-63-85 27-37-49
	2A 2B	CFM/SIDE THROW, FT.	675 450 25-31-42 22-27-37	900 600 29-37-51 25-31-42	1125 750 32-41-58 29-34-49	1350 900 37-44-61 31-37-54	1575 1050 37-48-66 32-39-58	1800 1200 41-51-71 34-42-61	2025 1350 42-54-75 37-48-65
	2C 2D 2E	CFM/SIDE THROW, FT.	787 31-37-54	1050 37-42-61	1312 41-49-70	1575 44-54-75	1837 48-58-80	2100 51-61-85	2362 54-65-90
	1A 1B	CFM/SIDE THROW, FT.	1115 460 34-42-59 24-29-41	1488 612 39-49-68 27-32-48	1861 764 44-56-76 31-37-54	2230 920 49-59-83 32-39-58	2605 1070 53-65-88 37-42-61	2976 1224 56-68-97 37-44-66	3349 1376 59-73-102 41-49-70
		CFM/SIDE THROW, FT.	1575 41-51-70	2100 39-58-80	2625 54-66-90	3150 58-70-99	3675 61-75-105	4200 66-80-114	4725 70-85-122
30 x 24 5.0 SQ. FT.	RETURN FACTORS —SP=3.1 TP NC + 8	CFM NC	1500 17	2000 25	2500 30	3000 35	3500 39	4000 43	4500 46
	4B 4C	CFM/SIDE THROW, FT.	A B	A B	A B	A B	A B	A B	A B
	4E	CFM/SIDE THROW, FT.	450 300 25-31-42 19-22-31	600 400 29-37-51 22-25-37	750 500 32-41-58 25-29-41	900 600 33-44-61 27-31-44	1050 700 37-48-66 29-32-48	1200 800 41-51-71 31-37-51	1350 900 42-54-75 32-37-54
	3A1	CFM/SIDE THROW, FT.	375 375 25-31-42 25-31-42	500 500 29-37-51 29-37-51	625 625 32-41-58 32-41-58	750 750 33-44-61 37-44-61	875 875 37-48-66 37-48-66	1000 1000 41-51-71 41-51-71	1125 1125 42-54-75 42-54-75
	3A2	CFM/SIDE THROW, FT.	600 300 29-37-51 19-22-31	800 400 34-41-58 22-25-37	1000 500 39-48-66 25-29-41	1200 600 41-51-70 27-31-44	1400 700 44-54-75 29-32-48	1600 800 49-59-80 31-37-51	1800 900 53-63-85 32-37-54
	2A 2B	CFM/SIDE THROW, FT.	515 470 31-37-54 25-31-42	687 625 37-42-61 29-37-51	859 782 41-49-70 32-41-58	1031 937 44-54-75 33-44-61	1203 1093 48-58-80 37-48-66	1375 1250 51-61-85 41-51-71	1548 1406 54-65-90 42-54-75
	2C 2D 2E	CFM/SIDE THROW, FT.	750 32-41-56	1000 37-48-65	1250 42-54-73	1500 48-58-78	1750 51-61-85	2000 54-66-90	2250 58-70-97
	1A 1B	CFM/SIDE THROW, FT.	900 600 37-42-63 29-37-51	1200 800 41-51-71 34-41-58	1500 1000 48-58-82 39-48-66	1800 1200 51-61-87 41-51-70	2100 1400 54-66-85 44-54-75	2400 1600 58-71-99 49-59-80	2700 1800 63-75-107 53-63-85
		CFM/SIDE THROW, FT.	1500 38-47-67	2000 45-54-76	2500 48-61-85	3000 54-65-95	3500 58-72-99	4000 62-76-106	4500 66-79-113

Notes:

- Core style 4E is sized to give equal flow as near as possible in directions A and B.
- For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: $A \times .82 = B$.

For performance notes, see page D37.

PERFORMANCE DATA:

MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
36 x 24 6.0 SQ. FT.	RETURN FACTORS —SP=3.3 TP NC + 8	CFM NC	1800 18	2400 25	3000 31	3600 36	4200 40	4800 43	5400 46
			A B	A B	A B	A B	A B	A B	A B
	4B 4C	CFM/SIDE THROW, FT.	600 300 29-37-51 19-22-31	800 400 34-41-58 22-25-37	1000 500 39-48-66 25-29-41	1200 600 41-51-70 27-31-44	1400 700 44-54-75 29-32-48	1600 800 49-59-80 31-37-51	1800 900 53-63-85 32-37-54
	4E	CFM/SIDE THROW, FT.	450 450 25-31-42 24-31-42	600 600 29-37-51 29-37-51	750 750 32-41-58 32-41-58	900 900 35-44-61 35-44-61	1050 1050 37-48-66 37-48-66	1200 1200 41-51-71 41-51-71	1350 1350 42-54-75 42-54-75
	3A1	CFM/SIDE THROW, FT.	750 300 31-37-54 19-22-31	1000 400 37-42-61 22-25-37	1250 500 41-49-70 25-29-41	1500 600 44-54-75 27-31-44	1750 700 48-58-80 29-32-48	2000 800 51-61-85 31-37-51	2250 900 54-65-90 32-37-54
	3A2	CFM/SIDE THROW, FT.	676 562 27-32-48 24-29-41	900 750 34-37-54 27-32-48	1125 937 34-42-61 31-37-54	1350 1125 37-48-66 32-39-58	1575 1312 39-51-71 35-42-61	1800 1500 42-54-75 37-44-66	2025 1687 48-58-80 41-49-70
	2A	CFM/SIDE THROW, FT.	900 32-41-56	1200 37-48-65	1500 42-54-73	1800 48-58-78	2100 51-61-85	2400 54-66-90	2700 58-70-97
	2B	CFM/SIDE THROW, FT.	900 32-41-56	1200 37-48-65	1500 42-54-73	1800 48-58-78	2100 51-61-85	2400 54-66-90	2700 58-70-97
	2C 2D	CFM/SIDE THROW, FT.	1200 600 37-42-63 25-31-42	1600 800 41-51-71 29-37-51	2000 1000 48-58-82 32-41-58	2400 1200 51-61-87 35-44-61	2800 1400 54-66-95 37-48-66	3200 1600 58-71-99 41-51-71	3600 1800 63-75-107 42-54-75
	2E	CFM/SIDE THROW, FT.	1200 600 37-42-63 25-31-42	1600 800 41-51-71 29-37-51	2000 1000 48-58-82 32-41-58	2400 1200 51-61-87 35-44-61	2800 1400 54-66-95 37-48-66	3200 1600 58-71-99 41-51-71	3600 1800 63-75-107 42-54-75
36 x 30 7.5 SQ. FT.	RETURN FACTORS —SP=3.4 TP NC + 8	CFM NC	2250 19	3000 26	3750 32	4500 37	5250 41	6000 44	6750 47
			A B	A B	A B	A B	A B	A B	A B
	4B 4C	CFM/SIDE THROW, FT.	657 468 29-37-51 20-25-34	875 625 34-41-58 24-29-39	1093 782 39-48-66 27-32-44	1313 937 41-51-70 29-37-49	1532 1093 44-54-75 31-37-53	1750 1250 49-59-80 32-41-56	1969 1406 53-63-85 37-42-59
	3A1	CFM/SIDE THROW, FT.	890 468 32-41-56 20-25-34	1187 625 37-48-65 24-29-39	1484 782 42-54-73 27-32-44	1781 937 48-58-78 29-37-49	2078 1093 51-61-85 31-37-53	2375 1250 54-66-90 32-41-56	2672 1406 58-70-97 37-42-59
	3A2	CFM/SIDE THROW, FT.	787 675 31-37-54 22-27-37	1050 900 37-42-61 25-31-42	1312 1125 41-49-70 29-34-49	1575 1350 44-54-75 31-37-54	1837 1575 48-58-80 32-39-58	2100 1800 51-61-85 37-42-61	2362 2025 54-65-90 37-48-65
	2A	CFM/SIDE THROW, FT.	1125 34-42-59	1500 39-49-68	1875 44-56-76	2250 49-59-83	2625 53-65-88	3000 56-68-97	3375 59-73-102
	2B	CFM/SIDE THROW, FT.	1125 34-42-59	1500 39-49-68	1875 44-56-76	2250 49-59-83	2625 53-65-88	3000 56-68-97	3375 59-73-102
	2C 2D	CFM/SIDE THROW, FT.	1312 938 37-42-63 29-37-51	1750 1250 41-51-71 34-41-58	2188 1562 48-58-82 39-48-66	2625 1875 51-61-87 41-51-70	3063 2187 54-66-95 44-54-75	3500 2500 58-71-99 49-59-80	3938 2812 63-75-107 53-63-85
	2E	CFM/SIDE THROW, FT.	1312 938 37-42-63 29-37-51	1750 1250 41-51-71 34-41-58	2188 1562 48-58-82 39-48-66	2625 1875 51-61-87 41-51-70	3063 2187 54-66-95 44-54-75	3500 2500 58-71-99 49-59-80	3938 2812 63-75-107 53-63-85
	1A 1B	CFM/SIDE THROW, FT.	2250 48-60-82	3000 56-68-94	3750 64-78-106	4500 68-82-116	5250 72-88-124	6000 78-94-134	6750 82-100-144

Notes:

- Core style 4E is sized to give equal flow as near as possible in directions A and B.
- For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is: $A \times .82 = B$.

CFM - cubic feet per minute
TP - total pressure - inches w.g.
T - throw in feet
NC - Noise Criteria (values) based on 10 dB room absorption, re 10⁻¹² watts.

Neck Velocity – feet per minute

Performance Notes:

- Throw values are given for terminal velocities of 150, 100 and 50 fpm under isothermal conditions. Data applies to ceiling mounted units when the maximum coanda effect applies. When no ceiling is present (exposed duct), throws are reduced by approximately 25%.
- Sound levels in performance tables are for steel construction – **Model 6500**. Apply the following corrections for aluminum construction – **Model 6200**.
 TP = Listed value x 1.25.
 NC = Listed value + 4.

- Performance data as tabulated is for supply air conditions. Correction factors for return air application - see next page.
- Correction factors for adjustable models - see next page.
- Correction factors for round inlets - see next page.
- Data derived from tests conducted in accordance with ANSI/ASHRAE Standard 70 – 2023.

PERFORMANCE DATA CORRECTIONS:

MODELS 6500 AND 6200

CORRECTION FACTORS FOR RETURN INLET

If the unit is used as a return inlet, the performance data is obtained by applying the return corrections, as follows:

- Add the NC correction at the left side of the table to the NC value listed in the performance table.
- Multiply the listed SP factor at the left side of the table by the total pressure (TP) listed at the top of the table.

CORRECTION FACTORS FOR MODELS 6550 AND 6250 (ADJUSTABLE PATTERN CONTROLLERS) – TABLE 2

Refer to the performance data for the **Models 6500 and 6200**. Apply the corrections from Table 2 to the data for square, 4-way core styles, as follows:

- NC = listed + correction
- Total Pressure = listed x factor
- Horizontal Throw = listed
- Vertical Throw = listed x factor

Apply the throw factor to the 50 fpm terminal velocity throw only.

Example:

18" x 18", **Model 6500**, 1350 cfm, 20°F temperature difference heating, vertical projection, (Page D23).

- NC = 31 + 6 = 37
- TP = .13 x 2.1 = .273
- Throw = 36 x .9 = 32.4 feet @ 50 fpm terminal velocity.

CORRECTION FACTORS WITH SQUARE TO ROUND INLET ADAPTOR – TABLE 3

- Add the NC correction factor from Table 3 and the NC value listed in the performance tables.
- Multiply the correction factor from Table 3 by the listed total pressure in the performance tables.
- Multiply the correction factor from Table 3 by the listed throws in the performance tables.

Example:

12" x 12" unit with 10" round adaptor handling 500 cfm supply air. (Page D23).

- NC = 23 + 7 = 30
- Total Pressure = .09 x 1.65 = 0.149
- Throw = 21 x 1.15 = 24.15 feet @ 50 fpm terminal velocity.

Example:

12" x 12" unit handling 600 cfm of return air. (Page D23).

- Return NC = 28 + 4 = 32.
- Return negative SP = 1.3 x (– .13) = – .169.

TABLE 2 Correction Factors 6550/6250 Adjustable

NECK SIZE	NC (add)		TOTAL PRESSURE (multiply)		VERTICAL THROW (multiply)			
					COOLING, ΔT	HEATING, ΔT		
	H	V	H	V	20°F	0°F	20°F	40°F
6 x 6	2	6	1.2	1.5	1.3	1.1	0.8	0.6
9 x 9	2	6	1.4	2.1	1.5	1.2	0.9	0.6
12 x 12	2	6	1.4	2.1	1.6	1.3	1.0	0.6
15 x 15	2	6	1.4	2.1	1.7	1.3	1.0	0.6
18 x 18	2	6	1.4	2.1	1.7	1.3	0.9	0.6
21 x 21	2	6	1.4	2.1	1.7	1.3	0.8	0.5
24 x 24	2	6	1.6	2.2	1.5	1.1	0.7	0.3

TABLE 3 Correction Factors for SR Adaptors

SQUARE INLET	ROUND INLET	NC (add)	TP (multiply)	THROW (multiply)		
				150	100	50
6 x 6	5	7	1.65	1.10	1.10	1.15
9 x 9	6	17	3.50	1.15	1.15	1.20
9 x 9	8	4	1.40	1.10	1.10	1.10
12 x 12	8	17	3.50	1.15	1.15	1.20
12 x 12	10	7	1.65	1.10	1.10	1.15
15 x 15	10	17	3.50	1.15	1.15	1.20
15 x 15	12	9	1.90	1.10	1.10	1.15
15 x 15	14	3	1.25	1.05	1.05	1.10
18 x 18	12	17	3.50	1.15	1.15	1.20
18 x 18	14	10	2.00	1.10	1.10	1.15
18 x 18	16	5	1.45	1.10	1.10	1.10
21 x 21	14	17	3.70	1.15	1.15	1.20
21 x 21	16	11	2.25	1.10	1.10	1.15
21 x 21	18	6	1.60	1.10	1.10	1.10
21 x 21	20	3	1.20	1.05	1.05	1.10
24 x 24	16	17	3.50	1.15	1.15	1.20
24 x 24	18	12	2.35	1.10	1.10	1.15
24 x 24	20	7	1.65	1.10	1.10	1.15
24 x 24	22	4	1.33	1.05	1.05	1.10