

## PERFORMANCE DATA:

### MODELS 6500 AND 6200 • SQUARE NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
6 x 6  .25 SQ. FT.	RETURN FACTORS —SP=1.1 TP NC + 1	CFM NC	75 —	100 10	125 17	150 22	175 26	200 31	225 35
	4A	CFM/SIDE THROW, FT.	19 4-5-8	25 4-6-10	31 6-8-10	37 6-8-11	44 8-9-12	50 8-9-12	56 9-10-13
	3A	CFM/SIDE THROW, FT.	19 28 4-5-8	25 38 5-8-11	31 47 6-8-10 8-10-14	37 56 6-8-11 8-11-15	44 66 8-9-12 9-12-16	50 75 8-9-12 9-12-17	56 85 9-10-13 10-13-18
	2S  2G	CFM/SIDE THROW, FT.	37 8-9-12	50 9-10-14	62 10-11-16	75 11-12-17	88 12-13-18	100 12-13-19	113 12-14-20
	1S	CFM/SIDE THROW, FT.	75 9-11-15	100 10-12-17	125 11-14-19	150 12-15-22	175 13-16-22	200 14-17-24	225 15-18-25
9 x 9  .56 SQ. FT.	RETURN FACTORS —SP=1.2 TP NC + 2	CFM NC	170 —	225 14	280 20	340 26	395 31	450 35	505 38
	4A	CFM/SIDE THROW, FT.	42 6-8-12	56 7-10-14	70 10-11-15	84 10-12-16	98 11-12-17	112 11-14-19	126 12-15-20
	3A	CFM/SIDE THROW, FT.	42 63 6-8-12	56 85 9-11-14	70 106 10-12-17	84 127 10-12-16 12-14-20	98 148 11-12-17 13-15-21	112 169 11-14-19 13-16-22	126 190 12-15-20 14-18-24
	2S  2G	CFM/SIDE THROW, FT.	84 9-10-15	112 11-13-18	141 12-15-20	169 13-16-22	197 14-17-23	225 15-18-25	253 16-19-28
	1S	CFM/SIDE THROW, FT.	169 12-15-20	225 14-17-23	282 16-19-26	338 17-22-29	394 18-22-31	450 19-24-33	507 22-25-35
12 x 12  1.0 SQ. FT.	RETURN FACTORS —SP=1.3 TP NC + 4	CFM NC	300 10	400 17	500 23	600 28	700 33	800 36	900 39
	4A	CFM/SIDE THROW, FT.	75 8-13-15	100 11-14-18	125 13-15-21	150 14-17-22	175 14-18-24	200 15-20-25	225 17-21-27
	3A	CFM/SIDE THROW, FT.	75 112 8-13-15	100 150 11-14-18	125 187 12-15-21	150 225 14-17-24	175 262 14-18-24 16-20-27	200 300 15-20-25 17-21-30	225 338 17-21-27 19-22-31
	2S  2G	CFM/SIDE THROW, FT.	150 12-15-20	200 15-17-25	250 17-19-27	300 18-20-29	350 19-21-31	400 20-25-34	450 21-25-36
	1S	CFM/SIDE THROW, FT.	300 16-20-28	400 18-22-32	500 21-25-37	600 22-26-39	700 23-28-41	800 25-29-41	900 28-33-47
15 x 15  1.56 SQ. FT.	RETURN FACTORS —SP=1.8 TP NC + 4	CFM NC	465 10	625 19	780 25	935 30	1090 33	1250 39	1400 41
	4A	CFM/SIDE THROW, FT.	117 13-16-21	156 14-18-24	195 16-19-27	234 18-21-29	273 19-22-30	312 20-24-33	350 21-26-35
	3A	CFM/SIDE THROW, FT.	117 175 13-16-21	156 234 14-17-23	195 292 16-19-27	234 351 18-21-29	273 409 19-22-30	312 468 20-24-33	350 527 21-26-35
	2S  2G	CFM/SIDE THROW, FT.	234 16-20-27	312 19-22-31	390 21-25-36	468 22-27-40	546 24-29-42	625 27-31-45	700 27-35-47
	1S	CFM/SIDE THROW, FT.	467 21-25-36	625 23-29-42	780 26-32-47	935 29-36-51	1090 30-39-55	1250 32-42-57	1400 36-44-61
18 x 18  2.25 SQ. FT.	RETURN FACTORS —SP=2.1 TP NC + 6	CFM NC	675 12	900 21	1125 27	1350 31	1575 36	1800 39	2025 42
	4A	CFM/SIDE THROW, FT.	168 15-19-25	225 17-20-29	281 19-24-32	337 20-25-36	394 22-27-37	450 24-29-41	506 25-31-43
	3A	CFM/SIDE THROW, FT.	168 253 15-19-25	225 338 17-22-29	281 422 17-20-29	337 506 20-25-36	394 590 22-27-37	450 675 24-29-41	506 760 25-31-43
	2S  2G	CFM/SIDE THROW, FT.	337 19-23-32	450 22-26-38	562 24-30-43	675 26-31-46	787 30-34-49	900 30-35-53	1012 32-39-55
	1S	CFM/SIDE THROW, FT.	675 25-33-45	900 30-36-51	1125 34-42-58	1350 36-45-61	1575 39-48-66	1800 43-52-70	2025 46-55-75

For performance notes, see page D37.

## PERFORMANCE DATA:

### MODELS 6500 AND 6200 • SQUARE NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033	400 .058	500 .090	600 .130	700 .177	800 .231	900 .293
21 x 21  3.06 SQ. FT.	RETURN FACTORS —SP=2.6 TP NC + 8	CFM NC	915 14	1225 22	1530 28	1835 32	2140 37	2450 40	2750 43
	4A	CFM/SIDE THROW, FT.	230 18-21-30	306 19-25-34	382 21-28-39	460 23-30-41	535 25-32-44	612 26-34-46	688 28-39-51
	3A	CFM/SIDE THROW, FT.	230 345 15-19-26 20-25-34	306 460 17-22-29 23-28-39	382 573 19-25-34 26-31-45	460 688 20-26-36 28-34-50	535 802 22-28-39 29-36-53	612 918 23-29-40 34-39-56	688 1030 25-34-45 34-43-59
	2S  2G	CFM/SIDE THROW, FT.	458 22-27-39	612 25-31-45	765 28-35-50	917 31-39-55	1070 32-42-59	1225 35-45-62	1375 39-48-66
	1S	CFM/SIDE THROW, FT.	917 29-37-51	1225 34-43-59	1530 39-50-67	1835 43-53-71	2140 46-56-77	2450 50-60-82	2750 53-64-88
24 x 24  4.0 SQ. FT.	RETURN FACTORS —SP=2.7 TP NC + 8	CFM NC	1200 15	1600 23	2000 29	2400 33	2800 37	3200 41	3600 44
	4A	CFM/SIDE THROW, FT.	300 20-24-33	400 24-27-40	500 27-31-44	600 29-33-47	700 31-35-51	800 33-40-55	900 35-40-58
	3A	CFM/SIDE THROW, FT.	300 450 20-24-33 23-28-39	400 600 24-27-40 26-31-46	500 750 27-31-44 29-36-52	600 900 29-33-47 31-38-56	700 1050 31-33-51 36-41-59	800 1200 33-40-55 36-43-64	900 1350 35-40-58 39-47-67
	2S  2G	CFM/SIDE THROW, FT.	600 25-33-45	800 30-36-51	1000 34-42-58	1200 36-45-61	1400 39-48-66	1600 43-52-70	1800 46-55-75
	1S	CFM/SIDE THROW, FT.	1200 35-40-59	1600 38-48-67	2000 45-54-77	2400 48-58-82	2800 51-62-90	3200 54-67-93	3600 59-70-101
30 x 30  6.25 SQ. FT.	RETURN FACTORS —SP=3.1 TP NC + 8	CFM NC	1875 16	2500 24	3125 30	3750 35	4375 39	5000 42	5625 46
	4A	CFM/SIDE THROW, FT.	469 25-31-42	625 29-36-48	782 34-40-55	937 36-44-61	1093 38-46-65	1250 40-50-69	1406 46-52-73
	3A	CFM/SIDE THROW, FT.	469 703 25-31-42 28-34-49	625 938 29-36-48 32-39-57	782 1172 34-40-55 35-44-64	937 1405 36-44-61 39-49-69	1093 1640 38-46-65 41-49-74	1250 1875 40-50-69 44-57-78	1406 2110 46-52-73 49-60-83
	2S  2G	CFM/SIDE THROW, FT.	937 32-40-55	1250 37-47-63	1562 42-53-72	1875 47-57-77	2187 50-60-83	2500 53-65-88	2812 57-68-95
	1S	CFM/SIDE THROW, FT.	1875 42-53-72	2500 49-60-83	3125 56-69-93	3750 60-72-102	4375 63-77-109	5000 69-83-116	5625 72-88-123
36 x 36  9.0 SQ. FT.	RETURN FACTORS —SP=3.6 TP NC + 9	CFM NC	2700 18	3600 25	4500 31	5400 36	6300 40	7200 44	8100 48
	4A	CFM/SIDE THROW, FT.	675 30-37-51	900 34-41-57	1125 39-46-67	1350 41-51-74	1575 44-53-78	1800 51-57-83	2025 51-64-87
	3A	CFM/SIDE THROW, FT.	675 1010 30-37-51 34-44-60	900 1350 34-41-57 40-48-68	1125 1687 39-46-67 46-56-78	1350 2025 41-51-74 48-60-82	1575 2362 44-53-78 52-64-88	1800 2700 51-57-83 58-70-94	2025 3038 51-64-87 62-74-100
	2S  2G	CFM/SIDE THROW, FT.	1350 40-45-67	1800 43-54-76	2250 50-61-86	2700 54-65-92	3150 58-70-101	3600 61-76-104	4050 67-79-113
	1S	CFM/SIDE THROW, FT.	2700 49-61-85	3600 59-70-99	4500 66-80-114	5400 72-85-122	6300 76-91-131	7200 82-97-142	8100 87-106-150

For performance notes, see page D37.

D

CEILING DIFFUSERS

## PERFORMANCE DATA:

### MODELS 6500 AND 6200 • RECTANGULAR NECK

NOMINAL NECK SIZE	BLOW PATTERNS	NECK VELOCITY TP	300 .033		400 .058		500 .090		600 .130		700 .177		800 .231		900 .293	
			CFM NC	1800 18	2400 25	3000 31	3600 36	4200 40	4800 43	5400 46						
36 x 24 6.0 SQ. FT.	RETURN FACTORS —SP=3.3 TP NC + 8	CFM NC	1800 18	2400 25	3000 31	3600 36	4200 40	4800 43	5400 46							
	4B  4C	CFM/SIDE THROW, FT.	600 300 29-37-51 19-22-31	800 400 34-41-58 22-25-37	1000 500 39-48-66 25-29-41	1200 600 41-51-70 27-31-44	1400 700 44-54-75 29-32-48	1600 800 49-59-80 31-37-51	1800 900 53-63-85 32-37-54							
	4E	CFM/SIDE THROW, FT.	450 450 25-31-42 24-31-42	600 600 29-37-51 29-37-51	750 750 32-41-58 32-41-58	900 900 35-44-61 35-44-61	1050 1050 37-48-66 37-48-66	1200 1200 41-51-71 41-51-71	1350 1350 42-54-75 42-54-75							
	3A1	CFM/SIDE THROW, FT.	750 300 31-37-54 19-22-31	1000 400 37-42-61 22-25-37	1250 500 41-49-70 25-29-41	1500 600 44-54-75 27-31-44	1750 700 48-58-80 29-32-48	2000 800 51-61-85 31-37-51	2250 900 54-65-90 32-37-54							
	3A2	CFM/SIDE THROW, FT.	676 562 27-32-48 24-29-41	900 750 34-37-54 27-32-48	1125 937 34-42-61 31-37-54	1350 1125 37-48-66 32-39-58	1575 1312 39-51-71 35-42-61	1800 1500 42-54-75 37-44-66	2025 1687 48-58-80 41-49-70							
	2A	CFM/SIDE THROW, FT.	900 32-41-56	1200 37-48-65	1500 42-54-73	1800 48-58-78	2100 51-61-85	2400 54-66-90	2700 58-70-97							
	2B	CFM/SIDE THROW, FT.	900 32-41-56	1200 37-48-65	1500 42-54-73	1800 48-58-78	2100 51-61-85	2400 54-66-90	2700 58-70-97							
	2C  2D	CFM/SIDE THROW, FT.	1200 600 37-42-63 25-31-42	1600 800 41-51-71 29-37-51	2000 1000 48-58-82 32-41-58	2400 1200 51-61-87 35-44-61	2800 1400 54-66-95 37-48-66	3200 1600 58-71-99 41-51-71	3600 1800 63-75-107 42-54-75							
	2E	CFM/SIDE THROW, FT.	1200 600 37-42-63 25-31-42	1600 800 41-51-71 29-37-51	2000 1000 48-58-82 32-41-58	2400 1200 51-61-87 35-44-61	2800 1400 54-66-95 37-48-66	3200 1600 58-71-99 41-51-71	3600 1800 63-75-107 42-54-75							
	1A  1B	CFM/SIDE THROW, FT.	1800 41-51-70	2400 48-58-80	3000 54-66-90	3600 58-70-99	4200 61-75-105	4800 66-80-114	5400 70-85-122							
36 x 30 7.5 SQ. FT.	RETURN FACTORS —SP=3.4 TP NC + 8	CFM NC	2250 19	3000 26	3750 32	4500 37	5250 41	6000 44	6750 47							
	4B  4C	CFM/SIDE THROW, FT.	657 468 29-37-51 20-25-34	875 625 34-41-58 24-29-39	1093 782 39-48-66 27-32-44	1313 937 41-51-70 29-37-49	1532 1093 44-54-75 31-37-53	1750 1250 49-59-80 32-41-56	1969 1406 53-63-85 37-42-59							
	3A1	CFM/SIDE THROW, FT.	890 468 32-41-56 20-25-34	1187 625 37-48-65 24-29-39	1484 782 42-54-73 27-32-44	1781 937 48-58-78 29-37-49	2078 1093 51-61-85 31-37-53	2375 1250 54-66-90 32-41-56	2672 1406 58-70-97 37-42-59							
	3A2	CFM/SIDE THROW, FT.	787 675 31-37-54 22-27-37	1050 900 37-42-61 25-31-42	1312 1125 41-49-70 29-34-49	1575 1350 44-54-75 31-37-54	1837 1575 48-58-80 32-39-58	2100 1800 51-61-85 37-42-61	2362 2025 54-65-90 37-48-65							
	2A	CFM/SIDE THROW, FT.	1125 34-42-59	1500 39-49-68	1875 44-56-76	2250 49-59-83	2625 53-65-88	3000 56-68-97	3375 59-73-102							
	2B	CFM/SIDE THROW, FT.	1125 34-42-59	1500 39-49-68	1875 44-56-76	2250 49-59-83	2625 53-65-88	3000 56-68-97	3375 59-73-102							
	2C  2D	CFM/SIDE THROW, FT.	1312 938 37-42-63 29-37-51	1750 1250 41-51-71 34-41-58	2188 1562 48-58-82 39-48-66	2625 1875 51-61-87 41-51-70	3063 2187 54-66-95 44-54-75	3500 2500 58-71-99 49-59-80	3938 2812 63-75-107 53-63-85							
	2E	CFM/SIDE THROW, FT.	1312 938 37-42-63 29-37-51	1750 1250 41-51-71 34-41-58	2188 1562 48-58-82 39-48-66	2625 1875 51-61-87 41-51-70	3063 2187 54-66-95 44-54-75	3500 2500 58-71-99 49-59-80	3938 2812 63-75-107 53-63-85							
	1A  1B	CFM/SIDE THROW, FT.	2250 48-60-82	3000 56-68-94	3750 64-78-106	4500 68-82-116	5250 72-88-124	6000 78-94-134	6750 82-100-144							

#### Notes:

1. Core style 4E is sized to give equal flow as near as possible in directions A and B.
2. For core styles 1A, 1B, 2A and 2B, the "A" direction is shown. Throw correction factor for "B" direction is:  $A \times .82 = B$ .

- CFM** - cubic feet per minute  
**TP** - total pressure - inches w.g.  
**T** - throw in feet  
**NC** - Noise Criteria (values) based on 10 dB room absorption, re  $10^{-12}$  watts.  
**Neck Velocity** – feet per minute

#### Performance Notes:

1. Throw values are given for terminal velocities of 150, 100 and 50 fpm under isothermal conditions. Data applies to ceiling mounted units when the maximum coanda effect applies. When no ceiling is present (exposed duct), throws are reduced by approximately 25%.
2. Sound levels in performance tables are for steel construction – **Model 6500**. Apply the following corrections for aluminum construction – **Model 6200**.  
TP = Listed value x 1.25.  
NC = Listed value + 4.
3. Performance data as tabulated is for supply air conditions. Correction factors for return air application - see next page.
4. Correction factors for adjustable models - see next page.
5. Correction factors for round inlets - see next page.
6. Data derived from tests conducted in accordance with ANSI/ASHRAE Standard 70 – 2006.

## PERFORMANCE DATA CORRECTIONS:

### MODELS 6500 AND 6200

#### CORRECTION FACTORS FOR RETURN INLET

If the unit is used as a return inlet, the performance data is obtained by applying the return corrections, as follows:

- Add the NC correction at the left side of the table to the NC value listed in the performance table.
- Multiply the listed SP factor at the left side of the table by the total pressure (TP) listed at the top of the table.

#### CORRECTION FACTORS FOR MODELS 6550 AND 6250 (ADJUSTABLE PATTERN CONTROLLERS) – TABLE 2

Refer to the performance data for the **Models 6500 and 6200**. Apply the corrections from Table 2 to the data for square, 4-way core styles, as follows:

- NC = listed + correction
- Total Pressure = listed x factor
- Horizontal Throw = listed
- Vertical Throw = listed x factor

Apply the throw factor to the 50 fpm terminal velocity throw only.

#### Example:

18" x 18", **Model 6500**, 1350 cfm, 20°F temperature difference heating, vertical projection, (Page D23).

- NC = 31 + 6 = 37
- TP = .13 x 2.1 = .273
- Throw = 36 x .9 = 32.4 feet @ 50 fpm terminal velocity.

#### CORRECTION FACTORS WITH SQUARE TO ROUND INLET ADAPTOR – TABLE 3

- Add the NC correction factor from Table 3 and the NC value listed in the performance tables.
- Multiply the correction factor from Table 3 by the listed total pressure in the performance tables.
- Multiply the correction factor from Table 3 by the listed throws in the performance tables.

#### Example:

12" x 12" unit with 10" round adaptor handling 500 cfm supply air. (Page D23).

- NC = 23 + 7 = 30
- Total Pressure = .09 x 1.65 = 0.149
- Throw = 21 x 1.15 = 24.15 feet @ 50 fpm terminal velocity.

#### Example:

12" x 12" unit handling 600 cfm of return air. (Page D23).

- Return NC = 28 + 4 = 32.
- Return negative SP = 1.3 x (-.13) = -.169.

**TABLE 2 Correction Factors 6550/6250 Adjustable**

NECK SIZE	NC (add)		TOTAL PRESSURE (multiply)		VERTICAL THROW (multiply)			
	H	V	H	V	COOLING, ΔT		HEATING, ΔT	
					20°F	0°F	20°F	40°F
6 x 6	2	6	1.2	1.5	1.3	1.1	0.8	0.6
9 x 9	2	6	1.4	2.1	1.5	1.2	0.9	0.6
12 x 12	2	6	1.4	2.1	1.6	1.3	1.0	0.6
15 x 15	2	6	1.4	2.1	1.7	1.3	1.0	0.6
18 x 18	2	6	1.4	2.1	1.7	1.3	0.9	0.6
21 x 21	2	6	1.4	2.1	1.7	1.3	0.8	0.5
24 x 24	2	6	1.6	2.2	1.5	1.1	0.7	0.3

**TABLE 3 Correction Factors for SR Adaptors**

SQUARE INLET	ROUND INLET	NC (add)	TP (multiply)	THROW (multiply)		
				150	100	50
6 x 6	5	7	1.65	1.10	1.10	1.15
9 x 9	6	17	3.50	1.15	1.15	1.20
9 x 9	8	4	1.40	1.10	1.10	1.10
12 x 12	8	17	3.50	1.15	1.15	1.20
12 x 12	10	7	1.65	1.10	1.10	1.15
15 x 15	10	17	3.50	1.15	1.15	1.20
15 x 15	12	9	1.90	1.10	1.10	1.15
15 x 15	14	3	1.25	1.05	1.05	1.10
18 x 18	12	17	3.50	1.15	1.15	1.20
18 x 18	14	10	2.00	1.10	1.10	1.15
18 x 18	16	5	1.45	1.10	1.10	1.10
21 x 21	14	17	3.70	1.15	1.15	1.20
21 x 21	16	11	2.25	1.10	1.10	1.15
21 x 21	18	6	1.60	1.10	1.10	1.10
21 x 21	20	3	1.20	1.05	1.05	1.10
24 x 24	16	17	3.50	1.15	1.15	1.20
24 x 24	18	12	2.35	1.10	1.10	1.15
24 x 24	20	7	1.65	1.10	1.10	1.15
24 x 24	22	4	1.33	1.05	1.05	1.10