PERFORMANCE DATA:

Models RNSA and ARNSA • 12 x 12 (300 x 300) Face Size

Nominal Neck Size	Neck Velocity, FPM		400	500	600	700	800	900	1000	1200	1400	1600
	Velocity Pressure		.010	.016	.023	.031	.040	.051	.063	.090	.122	.160
6" Dia.	Total Pressure	Horizontal	.019	.028	.039	.057	.074	.093	.121	.150	.192	.247
		Vertical	.023	.034	.057	.086	.110	.146	.168	.246	.316	.415
	Airflow, CFM		80	100	120	140	160	180	200	235	275	315
	Throw	Horizontal	1-2-4	2-3-6	2-3-6	3-4-7	3-5-7	4-5-8	4-6-10	6-7-11	6-8-11	6-9-12
		Vertical	1-1-2	2-2-5	2-2-6	2-3-5	2-3-5	3-5-6	3-4-7	4-5-8	5-6-9	5-7-10
	Noise Criteria	Horizontal	—	—	12	17	21	23	24	32	38	41
		Vertical	—	—	16	21	25	27	28	36	42	45
8" Dia.	Total Pressure	Horizontal	.020	.031	.043	.059	.071	.090	.110	.150	.200	.259
		Vertical	.032	.052	.063	.096	.12	.159	.186	.258	.342	.443
	Airflow, CFM		140	175	210	245	280	315	350	420	490	560
	Throw	Horizontal	2-3-6	3-5-8	4-5-8	4-7-10	5-7-12	6-9-14	8-9-15	8-10-16	10-12-18	11-14-20
		Vertical	2-2-3	3-4-7	3-5-6	4-6-9	4-6-9	5-7-10	6-8-11	7-9-12	8-9-13	9-10-14
	Noise Criteria	Horizontal	—	11	17	22	25	27	29	36	44	47
		Vertical	—	—	21	26	29	31	33	40	48	51

Models RNSA and ARNSA • 20 x 20 (500 x 500) Face Size

Nominal Neck Size	Neck Velocity, FPM		400	500	600	700	800	900	1000	1200	1400	1600
	Velocity Pressure		.010	.016	.023	.031	.040	.051	.063	.090	.122	.160
6" Dia.	Total Pressure	Horizontal	.017	.026	.038	.051	.067	.085	.105	.149	.202	.264
		Vertical	.023	.036	.052	.070	.091	.116	.143	.201	.274	.359
	Airflow, CFM		80	100	120	140	160	180	200	235	275	315
	Throw	Horizontal	1-2-4	2-2-5	2-3-6	2-4-6	3-5-6	4-5-7	4-5-7	4-6-8	5-6-8	5-7-9
		Vertical	1-1-2	2-2-3	2-2-4	2-3-5	2-4-5	3-5-6	3-5-7	4-5-8	4-6-9	5-7-10
	Noise Criteria	Horizontal	—	12	17	22	25	29	32	37	41	45
		Vertical	—	17	22	26	29	32	35	40	44	48
8" Dia.	Total Pressure	Horizontal	.019	.031	.044	.059	.077	.098	.120	.173	.235	.307
		Vertical	.031	.049	.070	.094	.122	.155	.192	.275	.373	.489
	Airflow, CFM		140	175	210	245	280	315	350	420	490	560
	Throw	Horizontal	2-3-5	2-3-7	3-4-8	3-5-8	3-5-9	4-6-9	4-7-10	5-8-11	6-8-12	7-9-12
		Vertical	1-1-4	1-2-5	2-3-6	3-4-6	3-4-8	4-5-8	4-6-9	4-7-10	5-7-10	6-8-12
	Noise Criteria	Horizontal	—	—	15	20	24	28	31	38	43	47
		Vertical	14	19	24	29	32	35	38	44	48	52
10" Dia.	Total Pressure	Horizontal	.024	.039	.056	.076	.098	.125	.153	.220	.299	.391
		Vertical	.041	.065	.094	.127	.165	.209	.258	.370	.502	.657
	Airflow, CFM		220	270	330	380	435	490	545	655	765	875
	Throws	Horizontal	2-4-7	3-5-8	4-6-9	4-7-10	5-7-10	6-8-11	6-8-12	7-9-13	8-10-14	9-11-15
		Vertical	1-2-4	1-3-6	3-5-7	3-5-8	4-5-9	4-6-10	5-6-10	5-7-11	6-8-12	7-9-12
	Noise Criteria	Horizontal	—	—	16	21	26	30	33	39	45	49
		Vertical	—	20	25	29	33	36	39	44	48	52

Performance Notes:

1. Throws are given at 150, 100 and 50 fpm terminal velocities under isothermal conditions.
2. All pressures are in inches w.g..
3. Horizontal throws are with ceiling coanda effect. For exposed duct mounting, multiply table values by x 0.7. Vertical throw is a free jet.
4. Noise Criteria (NC) are based on a room absorption of 10 dB, re 10^{-12} watts. Dash (—) in space denotes an Noise Criteria level less than 10.
5. Data derived from independent tests conducted in accordance with ANSI/ ASHRAE Standard 70-2006.

PERFORMANCE DATA:

Models RNSA and ARNSA • 24 x 24 (600 x 600) Face Size

Nominal Neck Size	Neck Velocity, FPM		400	500	600	700	800	900	1000	1200	1400	1600
	Velocity Pressure		.010	.016	.023	.031	.040	.051	.063	.090	.122	.160
6" Dia.	Total Pressure	Horizontal	.016	.024	.034	.047	.061	.078	.098	.129	.182	.240
		Vertical	.020	.031	.052	.080	.097	.124	.151	.218	.289	.390
	Airflow, CFM		80	100	120	140	160	180	200	235	275	315
	Throw	Horizontal	1-2-5	2-3-5	2-3-6	3-4-7	3-5-8	4-5-8	4-6-9	6-8-10	6-10-11	7-10-12
		Vertical	1-1-2	2-2-3	2-2-4	2-3-5	2-4-5	3-5-6	3-5-7	4-5-8	4-6-9	5-7-10
	Noise Criteria	Horizontal	—	—	—	13	17	20	22	28	32	36
		Vertical	—	—	—	15	19	22	24	30	34	38
8" Dia.	Total Pressure	Horizontal	.017	.026	.037	.049	.062	.08	.102	.131	.185	.243
		Vertical	.025	.04	.057	.077	.1	.126	.153	.221	.297	.393
	Airflow, CFM		140	175	210	245	280	315	350	420	490	560
	Throw	Horizontal	1-2-5	2-4-6	3-5-7	3-5-8	4-6-9	4-7-10	4-7-11	5-8-12	6-9-13	7-10-14
		Vertical	1-1-4	1-2-5	2-3-6	3-4-6	3-4-8	4-5-8	4-6-9	5-7-10	5-7-11	6-8-12
	Noise Criteria	Horizontal	—	—	13	18	21	22	26	32	38	42
		Vertical	—	—	17	20	25	26	30	36	42	46
10" Dia.	Total Pressure	Horizontal	.014	.021	.030	.039	.052	.065	.080	.112	.152	.194
		Vertical	.030	.048	.070	.092	.120	.161	.196	.264	.360	.450
	Airflow, CFM		220	270	330	380	435	490	545	655	765	870
	Throw	Horizontal	1-4-6	3-5-9	3-6-9	4-7-10	5-7-11	5-9-13	6-10-14	7-11-15	8-11-16	9-12-17
		Vertical	1-2-4	1-3-6	3-5-7	3-5-8	4-5-9	4-6-10	5-6-10	5-7-11	6-8-12	7-9-12
	Noise Criteria	Horizontal	—	10	15	21	26	30	33	38	43	45
		Vertical	—	14	19	25	31	34	37	42	47	49
12" Dia.	Total Pressure	Horizontal	.016	.025	.032	.043	.056	.072	.085	.129	.163	.216
		Vertical	.045	.069	.088	.120	.155	.204	.240	.360	.455	.585
	Airflow, CFM		315	390	470	550	630	705	785	950	1100	1255
	Throw	Horizontal	2-3-7	3-6-9	4-7-10	5-8-12	6-9-14	6-10-15	7-10-16	8-11-17	9-12-18	10-14-19
		Vertical	2-3-5	2-4-6	3-6-7	5-6-9	5-7-10	5-7-10	6-7-12	7-8-12	8-10-14	8-9-15
	Noise Criteria	Horizontal	—	15	22	25	30	33	36	43	45	48
		Vertical	12	18	25	28	33	36	39	46	48	51
14" Dia.	Total Pressure	Horizontal	.022	.037	.049	.057	.073	.092	.115	.147	.208	.262
		Vertical	.063	.101	.135	.160	.203	.261	.326	.411	.583	.640
	Airflow, CFM		425	530	635	745	855	960	1070	1285	1500	1710
	Throw	Horizontal	2-4-8	4-5-8	5-6-10	6-8-12	7-10-14	8-10-16	9-11-17	10-11-18	11-12-20	12-14-21
		Vertical	2-3-5	4-4-6	4-5-9	5-7-10	6-9-12	7-9-13	8-9-14	9-10-15	10-11-16	10-13-18
	Noise Criteria	Horizontal	—	16	22	25	29	33	36	40	42	48
		Vertical	11	19	25	28	32	36	39	43	45	51
15" Dia.	Total Pressure	Horizontal	.030	.041	.054	.062	.080	.100	.128	.155	.224	.308
		Vertical	.068	.110	.143	.165	.210	.271	.330	.425	.590	.660
	Airflow, CFM		490	615	735	860	985	1110	1230	1470	1720	1965
	Throw	Horizontal	5-6-8	5-8-9	8-9-11	9-10-12	10-10-13	11-12-15	12-12-16	12-14-18	14-15-20	15-17-23
		Vertical	3-4-6	3-4-7	5-6-8	6-7-9	6-8-10	8-9-11	10-11-12	11-12-14	11-14-16	12-16-18
	Noise Criteria	Horizontal	10	18	24	30	34	37	40	42	48	51
		Vertical	13	21	27	33	37	40	43	45	51	54

Performance Notes:

1. Throws are given at 150, 100 and 50 fpm terminal velocities under isothermal conditions.
2. All pressures are in inches w.g..
3. Horizontal throws are with ceiling coanda effect. For exposed duct mounting, multiply table values by x 0.7. Vertical throw is a free jet.
4. Noise Criteria (NC) are based on a room absorption of 10 dB, re 10^{-12} watts. Dash (—) in space denotes an Noise Criteria level less than 10.
5. Data derived from independent tests conducted in accordance with ANSI/ ASHRAE Standard 70-2006.