ARCHITECTURAL SQUARE CEILING DIFFUSERS

PERFORMANCE DATA:

Models UNI-AD • 24 x 24 (600 x 600) Face Size • 4-way Blow (360° Pattern)

Nominal Neck Size	Neck Velocity, FPM	400	500	600	700	800	900	1000	1200	1400	1600
	Velocity Pressure	.010	.016	.023	.031	.040	.051	.063	.090	.122	.160
12" Dia.	Total Pressure	.040	.063	.090	.123	.161	.203	.251	.361	.492	.643
	Airflow, CFM	315	390	470	550	630	705	785	940	1100	1255
	Horizontal Throws, Ft. H	5	7	8	9	11	12	14	15	17	18
	Vertical Projections, Ft. V	3-13	4-16	5-20	7-22	8-28	8-32	9-34	10-36	15-59	19-62
	Noise Criteria	—	—	13	16	21	25	29	35	41	46
14" Dia.	Total Pressure	.054	.083	.120	.163	.214	.270	.334	.481	.655	.855
	Airflow, CFM	425	530	635	745	850	955	1060	1270	1490	1695
	Horizontal Throws, Ft. H	7	9	11	13	15	17	19	21	22	24
	Vertical Projections, Ft. V	5-14	5-16	6-20	6-24	8-30	9-32	10-34	14-57	20-65	25-75
	Noise Criteria	_	_	14	18	23	27	30	37	43	48

Performance Notes:

1. Horizontal throws are given at a terminal velocity of 50 fpm and a 20°F cooling temperature differential.

Vertical projections are given at a terminal velocity of 50 fpm. Minimum projections are for a 40°F heating temperature differential and maximum projections are for a 20°F cooling differential.

2. All pressures are in inches w.g.. To obtain static pressure, subtract the velocitiy pressure from the total pressure.

3. Noise Criteria (NC) values are based upon 10dB room absorption, re 10⁻¹² watts. Noise Criteria values shown are for the horizontal discharge pattern. For downblast (damper open), deduct 5. Dash (—) in space indicates an Noise Criteria of less than 10.

4. Data derived from tests conducted in accordance with ANSI/ASHRAE Standard 70 – 2006.

D