


Performance Data • Hot Water Coil


Models: 37SW and 37SWST • Low Profile • Series Flow

Unit Size 1


1 Row (single circuit)




2 Row (multi-circuit)




3 Row (multi-circuit)



Water Pressure Drop



Air Pressure Drop



NOTES:

- Capacities are in MBH (kW), **thousands of Btu per hour (kilowatts)**.
- MBH (kW) values are based on a Δt (temperature difference) of 110°F (61°C) between entering air and entering water. For other Δt 's; multiply the MBH (kW) values by the factors below.

- Air Temperature Rise.

$$ATR (\text{°F}) = 927 \times \frac{\text{MBH}}{\text{cfm}}, \quad ATR (\text{°C}) = 829 \times \frac{\text{kW}}{\text{l/s}}$$
- Water Temp. Drop.

$$WTD (\text{°F}) = 2.04 \times \frac{\text{MBH}}{\text{GPM}}, \quad WTD (\text{°C}) = .224 \times \frac{\text{kW}}{\text{l/s}}$$
- Connections: 1 Row 1/2" (13), 2 and 3 Row 7/8" (22); O.D. male solder.

Correction factors at other entering conditions:

Δt °F (°C)	50 (28)	60 (33)	70 (39)	80 (44)	90 (50)	100 (56)	110 (61)	120 (67)	130 (72)	140 (78)	150 (83)
Factor	.455 (.459)	.545 (.541)	.636 (.639)	.727 (.721)	.818 (.820)	.909 (.918)	1.00 (1.00)	1.09 (1.10)	1.18 (1.18)	1.27 (1.28)	1.36 (1.36)

Altitude Correction Factors:

Altitude ft. (m)	Sensible Heat Factor
0 (0)	1.00
2000 (610)	0.94
3000 (914)	0.90
4000 (1219)	0.87
5000 (1524)	0.84
6000 (1829)	0.81
7000 (2134)	0.78