

**PERFORMANCE DATA**

**MODELS 59N(I) AND 59NR(I) • HORIZONTAL PATTERN • 9" (229) HIGH PLENUM (STD.)**

**24" (610) Long**

<b>6" Round Inlet</b>	Airflow, CFM	<b>60</b>	<b>80</b>	<b>100</b>	<b>120</b>	<b>140</b>	<b>160</b>	<b>180</b>	<b>200</b>
	Total Pressure	.039	.070	.110	.158	.215	.281	.355	.439
	Static Pressure	.033	.059	.093	.134	.182	.238	.303	.372
	Noise Criteria	–	16	22	27	31	34	36	39
	Horizontal Throw	3-5-13	5-9-15	6-11-17	8-12-19	10-15-20	11-14-21	12-16-23	13-17-24
<b>8" Oval Inlet</b>	Airflow, CFM	<b>60</b>	<b>80</b>	<b>100</b>	<b>120</b>	<b>140</b>	<b>160</b>	<b>180</b>	<b>200</b>
	Total Pressure	.023	.041	.064	.092	.125	.163	.207	.255
	Static Pressure	.021	.038	.059	.084	.115	.150	.190	.234
	Noise Criteria	–	–	17	23	26	29	31	34
	Horizontal Throw	3-5-13	5-9-15	6-11-17	8-12-19	10-15-20	11-14-21	13-16-23	13-17-24

**36" (914) Long**

<b>6" Round Inlet</b>	Airflow, CFM	<b>90</b>	<b>120</b>	<b>150</b>	<b>180</b>	<b>210</b>	<b>240</b>	<b>270</b>	<b>300</b>
	Total Pressure	.057	.101	.157	.227	.309	.403	.511	.630
	Static Pressure	.044	.078	.121	.174	.237	.310	.393	.484
	Noise Criteria	–	20	26	29	32	35	39	43
	Horizontal Throw	4-8-16	7-11-18	8-13-21	11-16-23	12-17-25	13-18-26	15-19-27	16-20-29
<b>8" Oval Inlet</b>	Airflow, CFM	<b>90</b>	<b>120</b>	<b>150</b>	<b>180</b>	<b>210</b>	<b>240</b>	<b>270</b>	<b>300</b>
	Total Pressure	.035	.062	.096	.139	.189	.247	.312	.386
	Static Pressure	.030	.053	.082	.118	.161	.211	.267	.329
	Noise Criteria	–	–	22	25	28	32	35	39
	Horizontal Throw	4-8-16	7-11-18	8-13-21	11-16-23	12-17-25	13-18-26	15-19-27	16-20-29

**48" (1219) Long**

<b>8" Oval Inlet</b>	Airflow, CFM	<b>120</b>	<b>160</b>	<b>200</b>	<b>240</b>	<b>280</b>	<b>320</b>	<b>360</b>	<b>400</b>
	Total Pressure	.039	.069	.107	.155	.211	.275	.348	.430
	Static Pressure	.030	.053	.083	.119	.162	.211	.268	.330
	Noise Criteria	–	–	20	24	29	33	36	40
	Horizontal Throw	5-9-18	8-13-22	10-15-24	13-18-26	16-20-28	17-21-30	18-22-32	20-24-33
<b>10" Oval Inlet</b>	Airflow, CFM	<b>120</b>	<b>160</b>	<b>200</b>	<b>240</b>	<b>280</b>	<b>320</b>	<b>360</b>	<b>400</b>
	Total Pressure	.028	.050	.079	.113	.154	.201	.255	.315
	Static Pressure	.024	.042	.066	.095	.130	.169	.214	.264
	Noise Criteria	–	–	18	22	27	30	33	37
	Horizontal Throw	5-9-18	8-13-22	10-15-24	13-18-26	16-20-28	17-21-30	18-22-32	20-24-33

**60" (1524) Long**

<b>8" Oval Inlet</b>	Airflow, CFM	<b>150</b>	<b>200</b>	<b>250</b>	<b>300</b>	<b>350</b>	<b>400</b>	<b>450</b>	<b>500</b>
	Total Pressure	.048	.085	.133	.191	.260	.340	.430	.532
	Static Pressure	.034	.060	.094	.135	.184	.241	.305	.376
	Noise Criteria	–	17	23	27	32	36	39	43
	Horizontal Throw	8-12-20	10-15-24	13-19-26	14-20-29	18-22-31	19-23-33	20-25-35	22-27-36
<b>10" Oval Inlet</b>	Airflow, CFM	<b>150</b>	<b>200</b>	<b>250</b>	<b>300</b>	<b>350</b>	<b>400</b>	<b>450</b>	<b>500</b>
	Total Pressure	.034	.061	.095	.137	.187	.244	.309	.381
	Static Pressure	.027	.048	.075	.108	.148	.193	.244	.301
	Noise Criteria	–	15	20	24	29	32	35	39
	Horizontal Throw	8-12-20	10-15-24	13-19-26	14-20-29	18-22-31	19-23-33	20-25-35	22-27-36

**Return Section**

<b>R Models</b>	Airflow, CFM/ft.	<b>30</b>	<b>40</b>	<b>50</b>	<b>60</b>	<b>70</b>	<b>80</b>	<b>90</b>	<b>100</b>
	Negative Static Pressure	-.010	-.018	-.027	-.038	-.050	-.063	-.079	-.098

**Performance Data Notes:**

1. Throws are given at 150, 100 and 50 fpm terminal velocities under isothermal conditions.
2. All pressures are in inches w.g..
3. Tested with one-way fixed horizontal discharge in the direction of the inlet and center down-blow deflector full open. Straight flexible duct connection.
4. Noise Criteria [NC] values based on a room absorption of 10 dB, re 10<sup>-12</sup> watts. Dash (–) in space denotes an Noise Criteria level less than 15.
5. Data derived from independent tests conducted in accordance with ANSI/ASHRAE Standard 70-2023.

## PERFORMANCE DATA NOTES:

### Model Series 5700

#### Performance Data Notes:

1. Throws are given at 150, 100 and 50 fpm terminal velocities under isothermal conditions.
2. All pressures are in inches w.g..
3. Cataloged throws are for a one-way horizontal air pattern. For divided airflow, deduce the airflow in each direction according to the number of slots, with the total airflow apportioned between the slots. Look up throw for the airflow in each direction according to the number of slots in that direction.
4. Noise Criteria [NC] values are based on a room absorption of 10 dB, re 10<sup>-12</sup> watts. Dash (-) in space denotes an Noise Criteria level less than 15.
5. Data derived from tests conducted in accordance with ANSI/ASHRAE Standard 70 – 2023.

### Models 59ND(I),59NDR(I)

#### Performance Data Notes:

1. Throws are given at 150, 100 and 50 fpm terminal velocities under isothermal conditions.
2. Total and Static Pressure are in inches w.g.
3. Noise Criteria (values) based on 10 dB room absorption, re 10<sup>-12</sup> watts.
4. Dash ( — ) in space indicates an NC level of less than 15.
5. Tested with one-way fixed horizontal discharge in the direction of the inlet and center down-blow deflector full open. Straight flexible duct connection.
6. Data derived from tests conducted in accordance with ANSI/ASHRAE Standard 70–2023.