

HOW TO SPECIFY

MODELS: 08SCL AND 08SH DUCT ACCESS DOORS

SUGGESTED SPECIFICATION:

Provide and install as shown on plans and/or schedules and at each fire damper location, duct access doors as manufactured by Nailor Industries, Inc., which meet the following criteria: Access door shall meet SMACNA requirements for systems up to 2 in. w.g. (500 Pa). Frame shall be constructed of die-formed 22 ga. (0.85) galvanized steel, complete with notched knock-over tabs for quick installation. Door shall be constructed of double skin die-formed 22 ga. (0.85) galvanized steel with 1" (25) insulation fully enclosed within door panel. A positive seal, polyethylene gasket shall be secured to each door.

For a fully removable access door secured with double camlocks and safety chain, standard of acceptance shall be Nailor Industries Model 08SCL.

For a hinged access door with camlock closure, standard of acceptance shall be Nailor Industries Model 08SH.