HOW TO SPECIFY

MODEL: 0720
LOW PROFILE CEILING DAMPERS

SUGGESTED SPECIFICATION:
Provide and install, as shown on plans and/or schedules, low profile ceiling dampers as manufactured by Nailor Industries, Inc., which meet the following criteria: Low Profile Curtain Type Ceiling Fire Dampers shall be UL Classified for use in all restrained and unrestrained UL Listed ceiling assemblies with fire resistance ratings of 3 hours or less. Dampers shall be tested and manufactured in accordance with UL 555C Standard for Ceiling Dampers and shall bear a UL label identifying the same.
Frame and blade shall be constructed of 22 ga. (0.85) galvanized steel. Curtain insulation shall be non-asbestos, UL Classified. Each ceiling damper shall be held open with a **(specifier to select)** 212°F (100°C) or 165°F (74°C) UL Listed fusible link. Ceiling dampers shall ship with and be installed in accordance to manufacturer's UL approved installation instructions. Information submitted for approval shall include same UL installation instructions.
Standard of acceptance shall be Nailor Industries Model 0720 Low Profile Curtain Type Ceiling Fire Dampers.