HOW TO SPECIFY

MODEL: 0130GC
GARBAGE CHUTE FIRE DAMPERS

SUGGESTED SPECIFICATION:
Provide and install, as shown on plans and/or schedules, garbage chute type fire dampers as manufactured by Nailor Industries, Inc. which meet or exceed the following criteria: Fire dampers shall be manufactured and tested in accordance with UL 555 Safety Standard for Fire Dampers. Use of this product may require approval from the local "Authority Having Jurisdiction", as UL does not recognize this application and there are no UL approved installation instructions.
Each fire damper shall be complete with a **(specifier select temperature)** 165°F (74°C) or 212°F (100°C) UL Listed fusible link. Garbage chute type fire dampers shall be equipped with closure springs and locking ramps suitable for horizontal mounting and shall be enclosed in a Type C housing, oversized to ensure all damper parts are not exposed to falling debris. Round collar of minimum 22 ga. (0.85) shall be provided on top side only, and shall be oversized for connection over chute. Each shipment of fire dampers shall include same installation instructions. Standard of acceptance shall be Nailor Model 0130GC garbage chute type fire dampers.